

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Base Cells	There are 40 beds in total in facility. Provide 5% to be accessible.	\$232.2.1.1 \$807.2.3 \$305.5	In cells with more than 25 beds, at least 5% of the beds shall have a clear floor space complying with 807.2.3. Provide at least 2 (5%) of beds that allow a 30" by 48" (762 mm by 1219 mm) min. clear floor space on at least one side of the bed, positioned for a parallel approach to the side of the bed (2010 ADA Fig. 305.5).	B	\$55.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Canine Training Area	Telephone is mounted at 60.5" (1537 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	B	\$293.14
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Canine Training Area	Video conference telephone is mounted at 62" (1575 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	B	\$293.14
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Canine Training Area	Fixed stool encroaches table clear floor space.	\$902.2	Relocate stool to provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space. 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Parking Area	There is a total of 60 parking spaces. There are no accessible parking spaces provided.	\$208.2	Provide at least (3) accessible parking spaces to comply with the minimum number required per 2010 ADA Table 208.2 Each accessible parking space must be 96" (2438 mm) min. wide with a 60" (1525 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions. Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor. (2010 ADA Figs. 502.3).	B	\$5,692.17
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Parking Area	There is no accessible route provided from accessible parking space to main entrance	\$402	Rework or repave accessible route to provide a 36" (914 mm) min. clear width accessible route with a cross slope not exceeding 2%.	B	\$3,500.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Parking Area	Potential location for the accessible parking spaces has a 4.5 % non-compliant running slope.	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$0.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General base	Telephone is mounted at 61" (1549 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$293.14
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General base	Video conference telephone is mounted at 62" (1575 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$293.14
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Base Cells	Fixed stool encroaches table clear floor space.	\$902.2	Relocate stool to provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space. 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$372.14
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Base Dining Area	Dining tables have a non-compliant 12" (305 mm) horizontal projection.	\$902.2	Provide 5% accessible tables with the surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground, with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance, that is 30" (760mm) min. wide and has a 17" (430 mm) horizontal projection.	C	\$0.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Base Dining Area	Dining tables have a non-compliant 26" (660 mm) knee clearance .	\$902.2	Provide 5% accessible tables with the surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground, with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance, that is 30" (760mm) min. wide and has a 17" (430 mm) horizontal projection.	C	\$0.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Base Dining Area	There are no accessible tables provided at the dining area.	\$226.1	Provide 5% accessible tables with the surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground, with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance, that is 30" (760mm) min. wide and has a 17" (430 mm) horizontal projection.	C	\$452.12
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Restroom Area	Sink knee clearance is 24" (610 mm) above the finished floor to bottom leading edge of fixture.	\$606.2.2	Rework sinks to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$500.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Restroom Area	Lavatory mirror is mounted at 52.5" (1334 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Restroom Area	Accessible toilet compartment is 36" (914 mm) wide due to small partition	\$604.8.1.1	Rework partition and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1). As an alternative, widen first stall from left to right.	C	\$2,109.74
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Restroom Area	Water closet has a 22" (559 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Restroom Area	Water closet seat is mounted at 16" (406 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Shower Area	Roll-in shower entryway is 28.75" (730 mm) wide.	\$608.2	Rework partitions to provide a 60" (1525 mm) min. clear entryway width to the shower compartment (Fig. 608.2.2).	C	\$1,500.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Shower Area	Roll-in shower stall has a 5" (127 mm) high curb.	\$608.7	Rework roll-in shower curb so it does not exceed 0.5" (12 mm) in height.	C	\$0.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Shower Area	Roll-in shower does not have grab bars.	\$608.3.1	Install grab bars on back and side walls at 6" (150 mm) max. from adjacent walls and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.3.2)	C	\$760.40
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Shower Area	Shower controls are mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	\$608.5.2	Relocate and mount shower controls above the grab bar at 48" (1220 mm) max. above the finished floor to the highest operable part (For a standard roll-in shower with out a seat only) (2010 ADA Fig. 608.5.2).	C	\$898.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Shower Area	Shower head is a fixed-type unit.	\$608.6	Replace or install additional shower spray unit with a hose that is 59" (1500 mm) min. in length and serves both as a fixed and hand-held unit. Per exception 608.6 A fixed shower head located at 48" (1220 mm) maximum above the shower finish floor shall be permitted instead of a hand-held spray unit in facilities that are not medical care facilities, long term facilities, transient lodging guest rooms, or residential	C	\$295.59
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Multipurpose Room	TV does not have the closed caption feature turned on.	\$36.303(e)	Ensure TV has the closed caption feature turned on during business hours.	C	\$0.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Multipurpose Room	Game table has a non-compliant 27" (686 mm) wide knee clearance.	\$902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$372.14
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Multipurpose Room	Suggestion box is mounted beyond required reach allowed for approach provided and is mounted at 57" (1443 mm) above the finished floor.	\$308.2.1	Lower or install suggestion box at 48" (1219 mm) max. above the finished floor to the slot (receptacle) (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Canine Training Area	Dryer controls are mounted in the back of the unit at 36" (914 mm) above the finished floor over a 22" (559 mm) obstruction.	\$611.3 \$308.3.1	Replace dryer with a new unit with controls mounted on the front panel. New unit must have controls mounted no more than 46" (1170 mm) above the ground over an obstruction no more than 34" (865 mm) high and 24" (610 mm) long, for a side approach to dryer (2010 ADA Fig. 308.3.1).	C	\$750.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Canine Training Area	Washer controls are mounted in the back of the unit at 36" (914 mm) above the finished floor over a 22" (559 mm) obstruction.	\$611.3 \$308.3.1	Replace washer with a new unit with controls mounted on the front panel. New unit must have controls mounted no more than 46" (1170 mm) above the ground over an obstruction no more than 34" (865 mm) high and 24" (610 mm) long, for a side approach to washer (2010 ADA Fig. 308.3.1).	C	\$750.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	Canine Training Area	Utility sink does not provide the required knee clearance.	\$606.2.2	Replace utility sink to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$500.00
Courts/Justice	Jail 2	781 Marietta Blvd Atlanta, GA 30318	General Restroom Area	Water closet has a 17" (432 mm) long side wall grab bar mounted at 32" (813 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$380.20

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Panel Review C	No emergency visual notification device in room.	§702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Therapy B Room	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Group Room	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom	Permanent room identifying signage does not have Braille or raised characters, is mounted on the door leaf and is mounted at 68.5" (1740 mm) above finished floor.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Laundry Room adjacent to Kitchen	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Food Court Room No. 1136	Signage containing tactile characters does not have the required clear floor space.	§703.4.2	Relocate signage or furniture to ensure that a clear floor space of 18" (455 mm) min. by 18" (455 mm) min. centered on the tactile characters, is provided beyond the arc of the door swing, between the closed position and 45° open position (2010 ADA Fig. 703.4.2).	B	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Visitation Room	Table and cabinet encroach over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Children's Playroom	Permanent room identifying signage does not have Braille or raised characters.	§703.3	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	LEAP Room	Permanent room identifying signage does not have Braille or raised characters.	§703.3	Provide signage displaying raised characters on non-glare contrasting surface, Grade 2 Braille text of same information.	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	LEAP Room	The computers in LEAP Room do not appear to provide accessible software	§508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic information technology.	B	\$1,095.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Work Room	Signage containing tactile characters does not have the required clear floor space.	§703.4.2	Relocate signage to ensure that a clear floor space of 18" (455 mm) min. by 18" (455 mm) min. centered on the tactile characters, is provided beyond the arc of the door swing, between the closed position and 45° open position (2010 ADA Fig. 703.4.2).	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Maneuvering clearance on the pull side of the door is 52" (1321 mm) deep for a parallel latch approach.	§404.2.4	Install an automatic door opener or rework door side partition to provide the required 24" (609 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach and 54" (1370 mm) min. deep clear floor area (For door with a closer) (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 3B	Lectern is mounted at 39.5" (1003 mm) above the finished floor to the top.	§902.3	Replace lectern to provide the top of the surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground, that allows a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection, with it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Fig. 306.3, 305.3 and 305.5).	B	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 3B	Clerk work desk has a non-compliant 26.5" (673 mm) knee clearance.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 3B	No sign provided indicating assistive listening devices are available in auditorium.	§219.1	Provide assistive listening systems in court room in compliance with 2010 ADA 219.1 and table 219.3 during events held at the court room. Post sign indicating that assistive listening systems are available upon request.	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Judge's Entrance to Courtroom No. 3B & 3C	There is no accessible route provided to judge's entrance.	§303.2	Install a lift or provide a ramp with 5% - 8.33% slopes and provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment	B	\$5,998.37
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 3D	Lectern is mounted at 39.5" (1003 mm) above the finished floor to the top.	§902.3	Replace lectern to provide the top of the surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground, that allows a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection, with it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Fig. 306.3, 305.3 and 305.5).	B	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 3D	Work station has a non-compliant 27.5" (698 mm) wide knee clearance.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection. Not in use.	B	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 3D	Desk has a non-compliant 26.5" (673 mm) knee clearance.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 3D	Judge's desk has a non-compliant 26.75" (679 mm) knee clearance.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 3D	No sign indicating assistive listening devices are available in auditorium.	§219.1	Provide assistive listening systems in court room in compliance with 2010 ADA 219.1 and table 219.3 during events held at the court room. Post sign indicating that assistive listening systems are available upon request.	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 4116	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 4000 verify room number ???	Furniture encroaches over maneuvering clearance on the push side of the door.	§404.2.4	Relocate chair to provide the required 12" (304 mm) min. maneuvering clearance on the push side of the door handle side (2010 ADA Fig. 404.2.4.1).	B	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Child Waiting Area	Signage containing tactile characters does not have the required clear floor space.	§703.4.2	Relocate furniture to ensure that a clear floor space of 18" (455 mm) min. by 18" (455 mm) min. centered on the tactile characters, is provided beyond the arc of the door swing, between the closed position and 45° open position (2010 ADA Fig. 703.4.2).	B	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Children's Playroom in Room 4094	Permanent room identifying signage does not have Braille or raised characters.	§703.3	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Children's Playroom in Room 4094	Garbage can and table encroach over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate encroaching items to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Office	Permanent room identifying signage does not have Braille or raised characters.	§703.3	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 4A	Clerk work desk has a non-compliant 26.75" (679 mm) knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 4A	No sign indicating assistive listening devices are available inside court room.	\$219.1	Provide assistive listening systems in court room in compliance with 2010 ADA 219.1 and table 219.3 during events held at the court room. Post sign indicating that assistive listening systems are available upon request.	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Courtroom No. 4C	There is no indication that assistive listening systems are provided in room	\$219.1	Provide assistive listening systems in council chambers in compliance with 2010 ADA 219.1 and table 219.3 during events held in the room. Post sign indicating that assistive listening systems are available upon request	B	\$2,779.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Accessible Parking Spaces on the Right	First access aisle from left to right has a 2.7 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$1,500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Path of Travel from Accessible Parking Spaces on the Left	No sign indicating path of travel to main entrance	\$216.1	Provide sign indicating accessible path of travel to main entrance.	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	First access aisle from the left has up to a 9.7 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	First accessible parking space from left to right has up to a 10.8 % non-compliant running slope.	\$502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	Second accessible parking space has a 13.8 % non-compliant running slope.	\$502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	Second access aisle has a up to a 10.7 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	Third accessible parking space has up to a 10.5 % non-compliant running slope.	\$502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	Fourth accessible parking space has a 11.5 % non-compliant running slope.	\$502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	Third access aisle has a 8.8 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	Fifth accessible parking space has a 9.1% non-compliant running slope.	\$502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	Sixth accessible parking space has a 7.7% non-compliant running slope.	\$502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Six Accessible Parking Spaces on the North East Side of Parking Lot	Fourth access aisle has a 6.3 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Accessible Route from Six Accessible Parking Spaces on the East Side to Ramp	Accessible route has non-compliant cross slopes of up to 9 %. (80 feet approx.)	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%. Alternative is to relocate parking spaces. Only eight accessible parking spaces are required for a lot with 400 spaces.	B	\$7,200.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Accessible Route from Public Rights of Way to Main Entrance	No sign indicating accessible entrance.	\$216	Post sign indicating accessible entrance.	B	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	LEAP Room	Maneuvering clearance on the pull side of the door is 16.75" (425 mm).	\$404.2.4	Install an automatic door opener or rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 2117 Youth Spark	Maneuvering clearance on the pull side of the door is 16.5" (419 mm).	\$404.2.4	Install an automatic door opener or rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Conference Room	Maneuvering clearance on the pull side of the door is 14" (356 mm).	\$404.2.4	Install an automatic door opener or rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Accessible Parking Space on the Left	Accessible parking space has 4.8 % non-compliant running slopes.	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Accessible Parking Space on the Left	Access aisle has 3.9 % non-compliant running slopes.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Accessible Parking Spaces on the Right	First accessible parking space from left to right has 3.1 % non-compliant running slopes.	\$502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Path of Travel from Accessible Parking Space on the Left	Accessible route has non-compliant cross slopes of 3 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$2,700.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Path of Travel from Seven Accessible Parking Spaces on the Right to Main Entrance	Accessible route has a non-compliant cross slope of 2.9 % that extends 75 ft (mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$6,750.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Path of Travel from Seven Accessible Parking Spaces on the Right To Main Entrance	Ramp with slopes of 5.7 % does not have the required handrails approx 60 ft (18.28 m)	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Figs. 505.4, 505.5, 505.6, 505.10.1.)	B	\$9,960.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Conference Room No.1133	Desk has a non-compliant 16" (406 mm) horizontal projection.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$452.12
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Therapy B Room	Furniture reduces passage width to TV.	\$403.5.1	Relocate furniture to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Therapy B Room	Furniture encroaches over TV clear floor space.	\$305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Therapy B Room	Ensure TV provides closed caption during business hours.	\$36.303(e)	Replace existing TV set if needed with a closed caption compatible unit or install a caption decoder system.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Group Room	Furniture encroaches over brochure rack clear floor space.	\$305.3	Relocate furniture or rack to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom	Paper towel dispenser protrudes into walkway, projecting more than 4" (102 mm) from back wall.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom	Water closet side wall grab bar is mounted at 13" (330 mm) perpendicular from rear wall to centerline of its inner flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$380.20
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom	Lavatory mirror is mounted at 54" (1372 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom	Toilet tissue dispenser is mounted at 38" (965 mm) from rear wall to the centerline.	\$604.9.6	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom	Baby changing station encroaches the required diameter wheelchair turnaround space in room.	\$304.3	Relocate baby changing station to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom	Diaper rack is mounted beyond required reach allowed for approach provided	\$308.3.1	Lower or install at 48" (1219 mm) max. above the finished floor for side approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Kitchen	Wall cabinets over the work surface are mounted too high.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Kitchen	Towel racks are mounted beyond required reach allowed for approach provided.	\$804.5	Lower or install at 48" (1219 mm) max. above the finished floor for side approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Kitchen	Trash bin encroaches over sink clear floor space.	\$305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Kitchen	Kitchen sink has objects under the sink.	\$804.3.3	Provide a kitchen cabinet free of objects under the sink.	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Laundry Room adjacent to Kitchen	Equipment encroaches over washer and dryer clear floor space.	\$305.3	Relocate equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Laundry Room adjacent to Kitchen	Front loading washers have the bottom opening to the laundry compartment located at 48" (1219 mm) above the finished floor.	\$611.3	Provide new washers with the bottom of the opening to the laundry compartment 15" (380 mm) to 36" (915 mm) max. above the finish floor (2010 ADA Fig. 611.4). Implement policy offering assistance upon request.	C	\$850.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Food Court Room No. 1136	Dining tables have a non-compliant 14" (356 mm) knee projection.	\$902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$452.12
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303		TV protrudes more than 4" (101 mm) from back wall.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Sanitary napkin dispenser requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$250.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Water closet side wall grab bar is mounted at 50" (1270 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$380.20
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Water closet is centered at 19" (483 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 57" (1454 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Baby changing station surface is mounted at 38" (965 mm) above finished floor when open.	\$902.2	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Door encroaches over baby changing station clear floor space.	\$305.3	Relocate baby changing station to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Water closet side wall grab bar is mounted at 50" (1270 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Readily achievable barrier removal has been provided within the existing footprint of this restroom.	C	\$150.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Water closet is centered at 19" (483 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 57" (1454 mm) above the finished floor. Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Baby changing station is mounted at 39" (991 mm) above finished floor when open.	\$902.2	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Room Next to Room No.1044	Counter is mounted at 44" (1118 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). Include policy to provide clipboard.	C	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Room Next to Room No.1044	Ensure TV provides closed caption during business hours.	\$36.303(e)	Replace existing TV set if needed with a closed caption compatible unit or install a caption decoder system.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Room Next to Room No.1044	DVD player protrudes into walkway, projecting 21" (533 mm) from back wall, and is mounted at 50.5" (1283 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 1090	Desk has a non-compliant 44" (1118 mm) clear floor space provided.	\$902.2	Relocate furniture to provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space.	C	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Interview Room	Tables and chairs encroach the required diameter wheelchair turnaround space in room.	\$304.3	Reconfigure furniture to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or T-shaped space (2010 ADA Fig. 304.3.2).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Probation Administration	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Probation Administration	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 56" (1422 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Probation Administration	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Elevators	Sanitizer is mounted beyond required reach allowed for approach provided	\$308.2.1	Lower or install at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Paper towel dispenser protrudes into walkway, projecting more than 4" (102 mm) from back wall.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Door encroaches over baby changing station clear floor space.	\$305.3	Relocate baby changing station to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Water closet side wall grab bar is mounted at 49" (1245 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Water closet is centered at 19" (483 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 62.25" (1581 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Baby changing station is mounted at 39" (991 mm) above finished floor when open.	\$902.2	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Maneuvering clearance on the pull side of the door is 53" (1346 mm) wide for a parallel latch approach.	\$404.2.4	Install an automatic door opener or rework door side partition to provide the required 24" (609 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach and 54" (1370 mm) min. deep clear floor area (For door with a closer) (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Citizen Panel Review	Water closet side wall grab bar is mounted at 49" (1245 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Citizen Panel Review	Water closet is centered at 19" (483 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Citizen Panel Review	Water closet has the rear wall grab bar mounted at 7.5" (190 mm) perpendicular from side wall to centerline of inner flange.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 12" (305 mm) min. to the centerline of the inner flange and mount between 33" and 36" (838 mm - 914 mm) above the floor to the top of the gripping surface (2010 ADA Fig. 604.5.2)	C	\$150.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Citizen Panel Review	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 63" (1600 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Citizen Panel Review	TV protrudes more than 4" (101 mm) from back wall.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.64
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Citizen Panel Review	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Citizen Panel Review	Baby changing station is mounted at 40" (1016 mm) above finished floor when opened.	\$902.2	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Area for Citizen Panel Review	TV provided does not have the closed caption feature turned on	\$36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Area for Citizen Panel Review	DVD player protrudes into walkway, projecting 23" (584 mm) from back wall, and is mounted at 61.25" (1556 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.17
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Citizen Panel Review Room No. 2022	Reception counter is mounted at 42" (1067 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework reception counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). Alternative is to provide clipboard.	C	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Children's Playground	TV provided does not have the closed caption feature turned on	\$36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Children's Playground	TV protrudes more than 4" (101 mm) from back wall.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.64
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom within Children's Playground	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom within Children's Playground	Water closet side wall grab bar is mounted at 13" (330 mm) perpendicular from rear wall to centerline of its inner flange.	\$604.5.1	Relocate side wall grab bar at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom within Children's Playground	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom within Children's Playground	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Restroom within Children's Playground	Chair and trash bin encroach over water closet clear floor space.	\$305.3	Relocate chair and trash bin to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom in LEAP Room	Water closet is centered at 19.25" (489 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom in LEAP Room	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 57.5" (1460 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom in LEAP Room	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom in LEAP Room	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 46.75" (1187 mm) above the finished floor	\$308.2.1	Lower or install soap dispenser at 44" (1118 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom in LEAP Room	Lavatory mirror is mounted at 40.75" (1035 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom in LEAP Room Side by Side	Water closet side wall grab bar is mounted at 13" (330 mm) perpendicular from rear wall to centerline of its inner flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom in LEAP Room Side by Side	Water closet is centered at 19.5" (495 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom in LEAP Room Side by Side	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom in LEAP Room Side by Side	TV protrudes more than 4" (101 mm) from back wall.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.64
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom in LEAP Room Side by Side	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 2117 Youth Spark	Counter is mounted at 41.5" (1054 mm) above the finished floor.	\$904.4.1	No transactions are conducted at this counter. No remedial work is necessary.	C	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 2117 Youth Spark	TV provided does not have the closed caption feature turned on	\$36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	The Junior League of Atlanta	TV provided does not have the closed caption feature turned on	\$36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	ACT Unit Room No. 2128	Reception counter is mounted at 42.5" (1080 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework reception counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). Clip board is provided.	C	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 2139 Intern	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 2141	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 3105	Reception counter is mounted at 43" (1092 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework reception counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). Clip board is provided.	C	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Room in Room No. 3105	Furniture encroaches over maneuvering clearance on the push side of the door.	§404.2.4	Relocate furniture to provide the required 12" (304 mm) min. maneuvering clearance on the push side of the door handle side (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Room in Room No. 3105	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Room in Room 3105	TV protrudes into walkway, projecting 24" (610 mm) from back wall, and is mounted at 77" (1956 mm) above the finished floor to its bottom leading edge.	§307.2a	Relocate and mount at or above 80" (2032 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	C	\$293.64
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Room in Room 3105	TV provided does not have the closed caption feature turned on.	§36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Room in Room 3105	TV protrudes into walkway, projecting 41" (1041 mm) from back wall, and is mounted at 76" (1930 mm) above the finished floor to its bottom leading edge.	§307.2a	Relocate and mount at or above 80" (2032 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	C	\$293.64
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Water closet side wall grab bar is mounted at 49" (1245 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Water closet side wall grab bar is mounted at 49" (1245 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 3134	Reception counter is mounted at 42.5" (1080 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework reception counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). Clip board is provided as an alternative.	C	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Area	TV provided does not have the closed caption feature turned on.	§36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Waiting Area	Brochures are mounted beyond required reach allowed for approach provided	§308.3.1	Lower or install at 46" (1168 mm) max. above the finished floor for side approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 4098	Reception counter is mounted at 42.5" (1080 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework reception counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). Clip board is provided as an alternative.	C	\$372.14
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room 4108 Child Advocate Attorney	Furniture encroaches over desk clear floor space	§305.3	Relocate encroaching furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Children's Playroom in Room 4094	TV provided does not have the closed caption feature turned on.	§36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Water closet side wall grab bar is mounted at 50" (1270 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Water closet is centered at 18.75" (476 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Water closet has the rear wall grab bar mounted at 7" (178 mm) perpendicular from side wall to centerline of inner flange.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 12" (305 mm) min. to the centerline of the inner flange from water closet centerline and mount between 33" and 36" (838 mm - 914 mm) above the floor to the top of the gripping surface (2010 ADA Fig. 604.5.2)	C	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 57.75" (1467 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom	Baby changing station is mounted at 39" (991 mm) above finished floor.	§902.2	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Water closet has the rear wall grab bar mounted at 50" (1270 mm) perpendicular from side wall to centerline of outer flange.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. to the center line of the outer flange and mount between 33" and 36" (838 mm - 914 mm) above the floor to the top of the gripping surface (2010 ADA Fig. 604.5.2)	C	\$149.95
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Baby changing station is mounted at 38" (965 mm) above finished floor.	§902.2	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Conference Room	Furniture encroaches passage width	§403.5.1	Relocate furniture to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	C	\$55.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Conference Room	TV provided does not have the closed caption feature turned on	§36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Judge's Entrance to Courtroom No. 4C	Ramp does not have handrail extensions.	§405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A	C	\$360.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Judge's Entrance to Courtroom No. 4C	Ramp does not provide a curb or barriers.	§405.9.2	Rework ramp to provide a curb or barrier that prevents the passage of a 4" (100 mm) diameter sphere, where any portion of the sphere is within 4" (100 mm) of the finished floor or ground surface (2010 ADA Fig 405.9.2)	C	\$1,600.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Cell No. G2	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Cell No. G2	Toilet tissue dispenser is mounted behind the water closet.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar - If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Cell No. M1	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter. For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Cell No. 304	Bench is 12" (508 by 305 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Cell No. 304	Bench is mounted at 20" (508 mm) above the finished floor.	§903.5	Rework bench to provide 17'-19" (431mm-485 mm) above the finished floor seat height with armrests and supportive backrest design (for ease in sitting/standing) (2010 ADA Fig.903.4).	C	\$452.12
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Cell No. 304	Toilet tissue dispenser is mounted behind the water closet.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar - If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)	C	\$131.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Cell No. 304	Water closet has the rear wall grab bar mounted at 36" (914 mm) perpendicular from side wall to centerline of outer flange.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. to the center line of the outer flange and mount between 33" and 36" (838 mm - 914 mm) above the floor to the top of the gripping surface (2010 ADA Fig 604.5.2)	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Cell No. 304	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 402	Water closet has the rear wall grab bar mounted at 36" (914 mm) perpendicular from side wall to centerline of outer flange.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. to the center line of the outer flange and mount between 33" and 36" (838 mm - 914 mm) above the floor to the top of the gripping surface (2010 ADA Fig 604.5.2)	C	\$0.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 402	Lavatory is mounted at 34.5" (889 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 402	Bench is mounted at 20" (508 mm) above the finished floor.	§903.5	Rework bench to provide 17'-19" (431mm-485 mm) above the finished floor seat height (2010 ADA Fig.903.4).	C	\$452.12
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Ramp Leading to Courtroom No. 3A	Ramp does not provide a curb or barriers.	§405.9.2	Rework ramp to provide a curb or barrier that prevents the passage of a 4" (100 mm) diameter sphere, where any portion of the sphere is within 4" (100 mm) of the finished floor or ground surface (2010 ADA Fig 405.9.2)	C	\$1,600.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Men's Restroom Next to Probation Administration	Door swings into water closet stall.	§603.2.3	Install double acting hinges on stall door to allow the required 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$150.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 4122	Maneuvering clearance on the pull side of the door is 15.5" (394 mm).	§404.2.4	Install an automatic door opener or rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$2,502.43
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Judge's Entrance to Courtroom No. 4C	Ramp has non-compliant running slopes of up to 10.5%.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%.	C	\$4,600.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Room No. 13	Intercom is mounted beyond required reach allowed to highest operable part for approach provided and is mounted at 49" (1245 mm) above the finished floor.	§308.3.1	Lower or install at 48" (1219 mm) max. above the finished floor for side approach to object (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$278.56
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Ramp Leading to Courtroom No. 3A	Ramp has non-compliant running slopes of up to 9.5%.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%.	C	\$4,600.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom	Accessible compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Courts/Justice	Judge Romae T. Powell Juvenile Justice Center	395 Pryor Street Atlanta, GA 30303	Women's Restroom Next to Citizen Panel Review	Accessible compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Conference Room No. JG03	No emergency visual notification device in room.	§702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Safe Families Room No. 2 P	Permanent room identifying signage does not have Braille or raised characters.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Safe Families Room No. 2 P	Desk knee clearance has a non-compliant horizontal projection.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2N	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2N	Lectern is mounted at 43.5" (1105 mm) above the finished floor to the top.	§808.4ph	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2N	Accessible route leading to the jury box has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2N	Accessible route leading to jury box has a 20" (508 mm) clear width.	§403.5.1	Relocate encroaching item or rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$293.14

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2N	Accessible route leading to the witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2N	Court reporter's station has a 24" (610 mm) wide knee clearance.	\$808.4	Provide court reporter's station is mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2M (ACCESSIBLE COURT ROOM)	Wheelchair area is not an integral part of the fixed seating plan in courtroom and/or there is no companion fixed seat next to the wheelchair area.	\$221.2.1.1	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$640.44
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2M (ACCESSIBLE COURT ROOM)	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. 2M (ACCESSIBLE COURT ROOM)	Lectern is mounted at a non-compliant height above the finished floor to the top.	\$808.4ph	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G40 (ACCESSIBLE COURT ROOM)	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G40 (ACCESSIBLE COURT ROOM)	There is no signage indicating that assistive listening systems are provided inside the court room.	\$703.7.2.4	Provide Assistive listening system in courtroom identified by a symbol indicating International Symbol of Access for Hearing Loss (2010 ADA Fig. 703.7.2.4).	B	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G40 (ACCESSIBLE COURT ROOM)	Lectern is mounted at 43" (1092 mm) above the finished floor to the top.	\$808.4ph	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G40 (ACCESSIBLE COURT ROOM)	Desk encroaches passage width leading to witness stand reducing it to 21" (533 mm).	\$403.5.1	Relocate desk to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$55.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G40 (ACCESSIBLE COURT ROOM)	Accessible route leading to judge's bench has 3 steps that produce a 18" (457 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a lift or ramp (2010 ADA Fig. 303.3).	B	\$1,695.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G33 (ACCESSIBLE COURTROOM)	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G33 (ACCESSIBLE COURTROOM)	Door has a non-compliant door opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G33 (ACCESSIBLE COURTROOM)	There is no signage indicating that assistive listening systems are provided inside the court room.	\$703.7.2.4	Provide Assistive listening system in courtroom identified by a symbol indicating International Symbol of Access for Hearing Loss (2010 ADA Fig. 703.7.2.4).	B	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G33 (ACCESSIBLE COURTROOM)	Accessible route leading to the court reporter's station has a step with a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Courtroom No. G33 (ACCESSIBLE COURTROOM)	Accessible route leading to judge's bench has 3 steps that produce a 18" (457 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a lift or ramp (2010 ADA Fig. 303.3).	B	\$3,695.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Lobby	Metal detector doorway opening has a clear width of 30" (762 mm).	\$404.2.3	Use a wand or install new metal detectors that provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Marshall's Department	Counter is mounted at 41" (1041 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Room No. JG02 Pre Trial Services and Alternatives Dispute	Counter is mounted at 40.5" (1029 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Georgia Department of Correction, Atlanta Probation Office JG54	Counter is mounted at 40" (1016 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Criminal Division State Court	Traffic division counter is mounted at 41" (1041 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Criminal Division State Court	Cashier counter is mounted at 41" (1041 mm) above the finished floor.	\$904.3.2	Rework (cut out) a portion of the cashier counter and mount at 38" (965 mm) max. above the finished floor to the top (2010 ADA Fig. 904.3.2).	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Corridor Leading to Adult Probation	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Adult Probation Room No. JB02	Counter is mounted at 41" (1041 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Connector From Building No. 160 to Building No. 141	Ramp handrails do not have extensions.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A	C	\$380.20
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Corridor Leading to Accessible Restroom	The two drinking fountains have the spout outlet (orifice height) mounted at 37" (940 mm) above the finished floor	\$602.4	Lower one drinking fountain unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$697.18
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-008	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-008	The stall door is not located at the partition farthest from the water closet	\$604.8.1.2	Rework stall to provide a door with the opening mounted at 4" max. from the side wall or partition farthest from the water closet.	C	\$2,119.74
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-008	The stall door is located at 12" (305 mm) from the side wall or partition farthest from the water closet	\$604.8.1.2	Rework stall to provide a door with the opening mounted at 4" max. from the side wall or partition farthest from the water closet.	C	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-008	Toilet dispenser is mounted 5" (127 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-008	Counter surface is mounted at 37" (940 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-008	Urinal clear floor space is 28.25" (718 mm) wide due to privacy partition.	\$605.3	Rework privacy partition so that it does not project more than 24" (610 mm) from the back wall, and provide a 30" by 48" (762 mm by 1219 mm) min. urinal clear floor space (2010 ADA Fig. 305.7.1).	C	\$250.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-007	Counter surface is mounted at 37.5" (952 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-007	Sanitary napkin dispenser requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$500.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-007	Hand dryer protrudes into walkway, projecting 9" (229 mm) from back wall, and is mounted at 50" (1270 mm) above the finished floor to its bottom leading edge.	§307.2r	Relocate or recess hand dryer so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$450.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-007	The stall door is not located at the partition farthest from the water closet.	§604.8.1.2	Stall must provide a door with the opening mounted at 4" max. from the side wall or partition farthest from the water closet.	C	\$2,119.74
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-007	The stall door is located at 12.5" (318 mm) from the side wall or partition farthest from the water closet.	§604.8.1.2	Stall must provide a door with the opening mounted at 4" max. from the side wall or partition farthest from the water closet.	C	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-007	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-007	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-007	Toilet tissue dispenser is mounted at 19.5" (495 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Corridor Leading to Restrooms	The two drinking fountains have the spout outlet (orifice height) mounted at 37" (940 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet.	C	\$3,137.43
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Paper towel dispenser protrudes into walkway, projecting 9" (229 mm) from back wall, and is mounted at 47" (1194 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Sanitary napkin dispenser protrudes into walkway, projecting 7" (178 mm) from back wall, and is mounted at 34" (864 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate or recess sanitary napkin dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Sanitary napkin dispenser requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$500.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Toilet tissue dispenser is mounted at 12.25" (311 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	The stall door is located at 12.75" (324 mm) from the side wall or partition farthest from the water closet.	§604.8.1.2	Stall must provide a door with the opening mounted at 4" max. from the side wall or partition farthest from the water closet.	C	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	The stall door is not located in partition or side wall farthest from water closet.	§604.8.1.2	Stall door must be mounted in the front partition or in the side wall or partition farthest from the water closet.	C	\$2,119.74
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor.	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	C	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Water closet seat in ambulatory stall is mounted at 15.5" (394 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Ambulatory accessible compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Door is swing into ambulatory accessible compartment (stall) clear floor space.	§604.8.2.2	Provide dual acting hinges or reverse door swing or reconfigure ambulatory accessible compartment (stall) to provide a 60"(1524 mm) min. depth and a minimum width of 35" and 37" (890 mm - 940 mm) max. (2010 ADA Fig. 604.8.2).	C	\$1,890.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Ambulatory stall doorway opening has a clear width of 22" (559 mm).	§404.2.3	Rework stall doorway (partitions) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	C	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom No. JCB-001	Toilet tissue dispenser is mounted at 11" (279 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	Toilet tissue dispenser is mounted at 14" (356 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	The stall door is not located in partition or side wall farthest from water closet.	§604.8.1.2	Stall door must be mounted in the front partition or in the side wall or partition farthest from the water closet.	C	\$2,119.74
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	Stall door is located at 12.5" (318 mm) from the side wall or partition farthest from the water closet.	§604.8.1.2	Stall must provide a door with the opening mounted at 4" max. from the side wall or partition farthest from the water closet.	C	\$0.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	Counter surface is mounted at 37.5" (952 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom No. JCB-002	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 50" (1270 mm) above the finished floor to highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Victim's Assistant's Program Room No. J314	Chair encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	D	\$55.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Safe Families	Permanent room identifying signage does not have Braille or raised characters.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Room No. J135 By Court Reporter's	Permanent room identifying signage does not have Braille or raised characters and it is mounted on the hinge side of the door.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Office of Alternatives Dispute Resolutions	Furniture encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	D	\$55.00
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Conference Room No. JG24	Permanent room identifying signage does not have Braille or raised characters and is mounted at 61.5" (1562 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Conference Room No. JG03	Permanent room identifying signage is mounted at 61.75" (1568 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Main Entrance to Building	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.	D	\$149.95
Courts/Justice	Justice Carnes Bldg	160 Pryor Street Atlanta, GA 30303	Office of the Solicitor General	This area will not be surveyed as a visitor's pass is required.	N/A	This area will not be surveyed as a visitor's pass is required.	N/A	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Left Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Left Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	A	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Police Department Floor	The entire floor is utilized by the Fulton County Police Department.	N/A	The Police Department is responsible for the programs and services offered on this floor. The responsibility is shared between the County and the Police Department. Assessments on this floor are limited to the public areas available within the Police Department. Please refer to Items 226 - 254.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	The counter at jury box is mounted at 38" (965 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Accessible route leading to jury box has a 11" (279 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Accessible route leading to court clerk's station has a 5.5" (140 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Accessible route leading to case manager's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Case manager's desk has a non-compliant 24.5" (622 mm) knee clearance due to keyboard.	\$902.2	Provide case manager's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	Doorway opening has a clear width of 26" (660 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	Lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	Accessible route leading to jury box has a 12" (305 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	The jury box or witness stand has a non-compliant clear floor space.	\$808.3	Remove 2 seats or install 2 removable seats at jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	Accessible route leading to court reporter's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	Accessible route leading to case manager's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Chambers Room No. T8655	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-40 at Courtroom No. 8F	Holding cell does not have the required diameter wheelchair turnaround space due to bench, it is 50" (1270 mm) wide	\$807.2.1	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space within the cell (2010 ADA Fig. 304.3.2).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-40 at Courtroom No. 8F	Holding cell bench is 19.5" (495 mm) deep.	\$807.2.2	Replace/rework to provide a bench fixed to a wall that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep, with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-40 at Courtroom No. 8F	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	B	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-40 at Courtroom No. 8F	Water closet has a 30" (762 mm) long side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	B	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-40 at Courtroom No. 8F	Lavatory is mounted at 35.5" (902 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-40 at Courtroom No. 8F	Lavatory knee clearance is 24.5" (622 mm) above the finished floor to bottom leading edge of fixture.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-40 at Courtroom No. 8F	Restroom does not provide the required diameter wheelchair turnaround space.	\$304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-48 at Courtroom No. 8F	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	B	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-48 at Courtroom No. 8F	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	B	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-48 at Courtroom No. 8F	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-48 at Courtroom No. 8F	Toilet tissue dispenser is mounted behind the front edge of the water closet.	\$604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	B	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-48 at Courtroom No. 8F	Partition encroaches over the water closet clearance.	\$604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Female Detention Area at Courtroom No. 8F	Drinking fountain spout outlet (orifice height) is mounted at 43" (1092 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	B	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-59 at Female Detention Area	Holding cell bench is 19" (483 mm) deep.	\$807.2.2	Replace/rework to provide a bench fixed to a wall that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep, with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-59 at Female Detention Area	Holding cell does not have the required diameter wheelchair turnaround space due to bench.	\$807.2.1	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space within the cell (2010 ADA Fig. 304.3.2).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-59 at Female Detention Area	Water closet has a 36" (914 mm) long side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	B	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-59 at Female Detention Area	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-59 at Female Detention Area	Lavatory knee clearance is 22.5" (572 mm) above the finished floor to bottom leading edge of fixture.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-59 at Female Detention Area	Toilet tissue dispenser is mounted behind the front edge of the water closet.	\$604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	B	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-59 at Female Detention Area	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	B	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell C-59 at Female Detention Area	Partition encroaches over the water closet clearance.	\$604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Fulton County Sheriff's Office	Counter is mounted at 48" (1219 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Room No. T9200 Warrant Service Division	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Waiting Area by Room No. T9200 Warrant Service Division	TV does not have the closed caption feature turned on.	\$36.303 (e)	Implement a policy to have the closed caption turned on during business hours.	B	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Counter at Warrant Service Division	Counter is mounted at 40" (1016 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). An alternative writing surface (clipboard) has been provided.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Maneuvering clearance on the pull side of the door is 40.75" (1035 mm) wide for a parallel latch approach to the accessible stall.	\$404.2.4	Rework door side partition to provide the required 42" (1066 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach to the stall.	B	\$1,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Family Law Information Center	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.36

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Family Law Information Center	Sign in counter surface is mounted at 35" (899 mm) above the finished floor.	§902.3	Rework to provide the top of the sign-in counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Family Law Information Center	Tables have a non-compliant 26" (660 mm) knee clearance.	§902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$287.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Family Law Information Center	Computer work station has a non-compliant 25.25" (641 mm) knee clearance.	§902.2	Provide workstation with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$287.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Lactation Room	Permanent room identifying signage does not have Braille or raised characters.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Emergency Exit at Jury Selection Room	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Lounge Area at Jury Selection Room	Maneuvering clearance on the pull side of the door is 16" (406 mm).	§404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	T700 Learning Center	Permanent room identifying signage does not have Braille or raised characters.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Reporter's Room	Permanent room identifying signage does not have Braille or raised characters.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	§802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	There is no companion seat provided next to the wheelchair area.	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Doorway opening has a clear width of 28" (711 mm) on each active leaf.	§404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Lectern is mounted at 35" (899 mm) above the finished floor to the top.	§808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	The counter at jury box is mounted at 37.5" (952 mm) above the finished floor to the top.	§808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Accessible route leading to jury box is reduced to 28" (711 mm) due to platform.	§403.5.1	Rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Accessible route leading to jury box has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Accessible route leading to case manager's station has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	The only means of access to the judge's bench is by stairs.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a lift (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room in Courtroom No. 4F	Maneuvering clearance on the pull side of the door is 28" (711 mm) deep for a parallel latch approach.	§404.2.4	Rework door side partition to provide the required 24" (609 mm) min. maneuvering clearance beyond the latch on the pull side of the door and 48" (1220 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Judge's Entrance to Courtroom No. 4E	The only means of access to the judge's bench is by stairs.	§403.4	Mitigate condition by means of a ramp or platform lift.	B	\$3,695.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	§802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	There is no companion seat provided next to the wheelchair area.	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Doorway opening has a clear width of 29" (737 mm) on each active leaf.	§404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Lectern is mounted at 35" (899 mm) above the finished floor to the top.	§808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	The fold counter at jury box is mounted at 37" (940 mm) above the finished floor to the top.	N808.4	Provide at least one counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Accessible route leading to jury box has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	The jury box or witness stand has a non-compliant clear floor space.	§808.3	Remove two seating spaces or provide two removable spaces at jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Accessible route leading to the witness stand has a clear width of 26" (660 mm) due to guardrail.	§403.5.1	Remove guard rail or rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Accessible route leading to clerks station has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4E	Accessible route leading to case manager's station has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Judge's Entrance to Courtroom No. 4D	The only means of access to the judge's bench is by stairs.	\$403.4	Mitigate condition by means of a ramp or lift (2010 ADA Fig. 303.3).	B	\$3,695.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 4D	Holding cell does not have the required diameter wheelchair turnaround space.	\$807.2.1	Reconfigure bench to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space within the cell (2010 ADA Fig. 304.3.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Courtroom No. 4D	Holding cell does not have the required diameter wheelchair turnaround space.	\$807.2.1	Reconfigure the partition to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space within the cell (2010 ADA Fig. 304.3.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.40
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	Podium is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	The counter at jury box is mounted at 37" (940 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible counter table mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	Accessible route leading to jury box has a 12" (305 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	TV protrudes into walkway, projecting more than 4" (102 mm) from back wall, and is mounted below 80" (2032 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess TV so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4D	Accessible route leading to case manager's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.40
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Doorway opening has a clear width of 28.5" (724 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Podium is mounted at 40" (1016 mm) above the finished floor to the top.	\$808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	The counter at jury box is mounted at 38" (965 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Accessible route leading to jury box has a 12" (305 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Accessible route leading to case manager's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	Case manager's desk has a non-compliant 26" (660 mm) knee clearance.	\$902.2	Provide case manager's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4C	The only means of access to the judges bench is by stairs.	\$403.3	Mitigate condition by means of a ramp or platform lift.	B	\$3,695.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room at Courtroom No. 4C	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lb.	B	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	The only means of access to the judge's bench is by stairs.	\$403.4	Rework area to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a lift or ramp (2010 ADA Fig. 303.3).	B	\$3,695.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$604.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Doorway opening has a clear width of 28.25" (718 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Lectern is mounted at 39.5" (1003 mm) above the finished floor to the top.	\$808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	The counter at jury box is mounted at 37.5" (952 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Accessible route leading to jury boxes has a 12" (305 mm) vertical change in level due to the steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a curb ramp or ramp (2010 ADA Fig. 303.3).	B	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Accessible route leading to case management's desk has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a curb ramp or ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom No. 3A	Maneuvering clearance on the pull side of the door is 7" (178 mm).	§404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1). This door is opened by security personnel only.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom No. 3A	Bench is 19.5" (495 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3A	Bench is 19.5" (495 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	§802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	There is no companion seat provided next to the wheelchair area.	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	Doorway opening has a clear width of 28.5" (724 mm) on each active leaf.	§404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	Lectern is mounted at 40" (1016 mm) above the finished floor to the top.	§808.4ph	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished floor, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	The counter at jury box is mounted at 38" (965 mm) above the finished floor to the top.	N808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished floor, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	Accessible route leading to jury box has a 12" (305 mm) vertical change in level due to steps.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	Accessible route leading to Clerk's station has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	Accessible route leading to case manager's desk has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3B	The only means of access to the judge's bench is by stairs.	§403.4	Provide an alternative accessible location or mitigate condition by means of a ramp or platform lift.	B	\$3,695.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	§802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.40
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	There is no companion seat provided next to the wheelchair area.	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Doorway opening has a clear width of 26" (660 mm) on each active leaf.	§404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Lectern is mounted at 40" (1016 mm) above the finished floor to the top.	§808.4ph	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished floor, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	The counter at jury box is mounted at 36.5" (927 mm) above the finished floor to the top.	N808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished floor, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Accessible route leading to jury box has a 12" (305 mm) vertical change in level due to steps.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Accessible route leading to case manager's desk has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Door has a non-compliant opening force.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Bench is 19.5" (495 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom No. 3D	Holding cell is 47.5" (1206 mm) wide and does not provide the required diameter wheelchair turnaround space.	§807.2.1	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space within the cell (2010 ADA Fig. 304.3.2).	B	\$6,052.63
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom No. 3D	Bench is 19.5" (495 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.08
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	§802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	There is no companion seat provided next to the wheelchair area.	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	The counter at jury box is mounted at 37" (940 mm) above the finished floor to the top.	N808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished floor, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	Accessible route leading to jury box has a 12" (304 mm) vertical change in level due to steps.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	TV protrudes into walkway, projecting more than 4" (102 mm) from back wall, and is mounted below 80" (2032 mm) above the finished floor to its bottom leading edge.	\$307.2	Relocate or recess TV so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	B	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	Accessible route leading to case manager's desk has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room 3E	The only means of access to the judge's bench is by stairs.	\$403.4	Mitigate condition by means of a ramp or platform lift.	B	\$3,695.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	Doorway opening has a clear width of 28" (711 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	lectern is mounted at 40" (1016 mm) above the finished floor to the top.	\$808.4ph	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished floor, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	The counter at jury box is mounted at 37" (940 mm) above the finished floor to the top.	N808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished floor to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	Accessible route leading to jury stand has a 12" (304 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3F	Accessible route leading to case manager's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room at Courtroom No. 3F	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lb.	B	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Holding Cell No. 1 at Courtroom No. 3F (Left Side)	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lb. This door is opened by security personnel only, no remedial work is necessary.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Holding Cell No. 1 at Courtroom No. 3F (Left Side)	Maneuvering clearance on the pull side of the door is 11" (279 mm).	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1). This door is opened by security personnel only, no remedial work is necessary.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom No. 3F	Bench is 19.5" (495 mm) wide.	\$903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3F	Bench is 19.5" (495 mm) wide.	\$903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	Doorway opening has a clear width of 28" (711 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished floor, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	The counter at jury box is mounted at 37.75" (959 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished floor to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	Accessible route leading to jury stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a curb ramp or ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7E	Accessible route leading to case manager's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor in jury Deliberation Room at Courtroom No. 7E	Counter surface is mounted at 39.75" (1010 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Holding Cells at Courtroom No. 7E	Maneuvering clearance on the pull side of the door is 9" (229 mm).	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1). This door is opened by security personnel only, no remedial work is necessary.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Interview Room No. 1 at Courtroom No. 7E	Bench is 19.5" (495 mm) wide.	\$903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 7E	Bench is 19.5" (495 mm) wide.	\$903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	There is no companion seat provided.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	Lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	The counter at jury box is mounted at 37.25" (946 mm) above the finished floor to the top.	\$808.4	Provide at least one counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	Accessible route leading to jury box has a 12" (305 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	Accessible route leading to defendants stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	TV protrudes into walkway, projecting more than 4" (102 mm) from back wall.	\$307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	Accessible route leading to clerk's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 7F	Accessible route leading to case manager has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	Lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	The jury box or witness stand has a non-compliant clear floor space.	\$808.3	Remove 2 seats or provide 2 removable seats at jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	Desk at witness stand has a non-compliant 25.75" (654 mm) knee clearance.	\$902.2	Provide witness stand desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	Witness stand desk surface is mounted at 27.5" (698 mm) above the finished floor.	\$902.3	Rework to provide the top of the desk surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	Court reporter's desk has a non-compliant 26" (660 mm) knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	Court Reporter's desk surface is mounted at 27.5" (698 mm) above the finished floor.	\$902.3	Rework to provide the top of the court reporter's desk surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	Case manager's desk has a non-compliant 26" (660 mm) knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5A (ACCESSIBLE)	The only means of access to the judge's bench is by stairs.	\$403.4	Mitigate condition by means of a ramp or platform lift.	B	\$3,695.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to jury Deliberation Room at Courtroom No. FA	Ramp handrails do not have extensions.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment	B	\$360.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to jury Deliberation Room at Courtroom No. FA	Maneuvering clearance on the pull side of the door is 16" (406 mm).	\$404.2.4	Provide an automatic door opener or rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,900.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Accessible Route Leading to Holding Cell at Courtroom No. 5A	Ramp has a non-compliant surface slope of 10.2 %.	\$405.2	Rework ramp to provide a running slope not exceeding 8.33%. Per ADA section 4.1.6 (j) it is technically infeasible to alter the ramp as the changes have little likelihood of being accomplished due to space limitations	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Accessible Route Leading to Holding Cell at Courtroom No. 5A	Maneuvering clearance on the pull side of the door is 8.5" (216 mm).	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1). This door is opened by security personnel only, no remedial work is necessary.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Interview Room No. 5 at Courtroom No. 5A	Interview room does not provide the required diameter wheelchair turnaround space in room.	\$304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	B	\$6,052.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Interview Room No. 5 at Courtroom No. 5A	Fixed table has a non-compliant knee clearance and non-compliant clear floor space.	\$902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Bench is mounted at 16" (406 mm) above the finished floor.	\$803.4	Provide a 20" to 24" (508 mm - 609 mm) max. deep bench, that is 42" (1065 mm) long minimum, fixed to a wall, and mounted 17" min. to 19" max. (431 mm-482 mm) above the finished floor to top of bench.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Bench is 18" (457 mm) deep.	\$903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5B	Maneuvering clearance on the pull side of the door is 48" (1219 mm) deep due to ramp run.	\$404.2.4	Provide automatic door opener to comply with the 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,595.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5B	Ramp has a 48" (1219 mm) top landing.	\$405.7.3	Rework ramp to provide 60" (1524 mm) min. long top landing for runs rising over 30" (762 mm) (2010 ADA Fig. 405.7).	B	\$4,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5B (ACCESSIBLE)	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5B (ACCESSIBLE)	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5B (ACCESSIBLE)	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5B (ACCESSIBLE)	Lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5B (ACCESSIBLE)	The jury box or witness stand has a non-compliant clear floor space.	\$808.3	Rework jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5B (ACCESSIBLE)	Witness stand desk has a non-compliant 26" (660 mm) knee clearance.	\$902.2	Provide witness stand desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5B (ACCESSIBLE)	Court reporter's desk has a non-compliant 26" (660 mm) knee clearance.	\$902.2	Provide court reporter's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5B (ACCESSIBLE)	Case managers desk has a non-compliant 26.5" (673 mm) knee clearance.	\$902.2	Provide case manager's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to jury Deliberation Room at Courtroom No. 5B	Ramp has a non-compliant surface slope of up to 9.7 %.	\$405.2	Rework ramp to provide a running slope not exceeding 8.33%.	B	\$4,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to jury Deliberation Room at Courtroom No. 5B	Ramp does not have the required handrail extensions.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 404.2.4.1).	B	\$360.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room at Courtroom No. 5B	Maneuvering clearance on the pull side of the door is 16" (406 mm).	\$404.2.4	Install an automatic door opener or rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,595.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room at Courtroom No. 5B	Door has a non-compliant opening force of 9 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5C	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5C	lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4ph	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5C	The jury box or witness stand has a non-compliant clear floor space.	\$808.3	Remove 2 chairs or provide 2 removable chairs in jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5C	Witness stand desk has a non-compliant 26.5" (673 mm) knee clearance.	\$902.2	Provide witness stand desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5C	Court reporter's desk has a non-compliant 26" (660 mm) knee clearance.	\$902.2	Provide court reporter's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Area in Courtroom No. 5C	Maneuvering clearance on the pull side of the door is 17" (432 mm).	\$404.2.4	Rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,583.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Area in Courtroom No. 5C	Maneuvering clearance on the pull side of the door has non-compliant slope of 9.5 %.	\$404.2.4	Rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$900.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Interview Room at Courtroom No. 5C	Fixed tables have a non-compliant knee clearance.	\$902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1at Courtroom No. 5C	Bench is 18" (457 mm) deep.	\$903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	Maneuvering clearance on the pull side of the door is 48" (1219 mm) deep due to ramp landing.	\$404.2.4	Rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$4,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.40
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	Witness stand desk has a non-compliant 25.5" (648 mm) knee clearance.	\$902.2	Provide witness stand desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	The jury box or witness stand has a non-compliant clear floor space.	\$808.3	Remove 2 chairs or provide 2 removable chairs in jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	Court reporter's desk has a non-compliant 26" (660 mm) knee clearance.	\$902.2	Provide court reporter's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	Court case manager's desk has a non-compliant 26.5" (673 mm) knee clearance.	\$902.2	Provide court case manager's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	Court reporter's desk has a non-compliant 26" (660 mm) knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5D	TV protrudes into walkway, projecting 15" (381 mm) from back wall, and is mounted at 71.5" (1816 mm) above the finished floor to its bottom leading edge.	\$307.2	Relocate or recess TV so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	B	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room in Courtroom No. 5D	The sloped area of the ramp encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Provide automatic door opener to comply the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,595.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Accessible Route Leading to Courtroom No. 5E	Ramp has a 48" (1219 mm) top landing.	\$405.7.3	Rework ramp to provide 60" (1524 mm) min. long top landing for runs rising over 30" (762 mm) (2010 ADA Fig. 405.7).	B	\$4,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Accessible Route Leading to Courtroom No. 5E	Maneuvering clearance on the pull side of the door is 48" (1219 mm) deep due to ramp.	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5E	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.40
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5E	There is no companion seat provided next to the wheelchair area.	\$802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5E	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5E	lectern is mounted at 35" (889 mm) above the finished floor to the top.	§808.4	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5E	The jury box or witness stand has a non-compliant clear floor space.	§808.3	Remove 2 chairs or provide 2 removable chairs in jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5E	Witness stand desk has a non-compliant 26" (660 mm) knee clearance.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5E	Court reporter's desk has a non-compliant 26" (660 mm) knee clearance.	§902.2	Provide court reporter's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5E	Case manager's desk has a non-compliant 26.5" (673 mm) knee clearance.	§902.2	Provide case manager's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room in Courtroom No. 5D	The sloped area of the ramp encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Provide automatic door opener to comply the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room in Courtroom No. 5D	Ramp has a non-compliant surface slope of 12.5 %.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%.	B	\$4,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Accessible Route Leading to Holding Cells in Courtroom No. 5E	Ramp has a non-compliant surface slope of 9.3 % and does not have handrails.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%.	B	\$1,960.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Interview Room in Holding Cells at Courtroom No. 5E	Interview room does not provide the required diameter wheelchair turnaround space.	§304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	B	\$1,960.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Interview Room in Holding Cells at Courtroom No. 5E	Fixed tables have a non-compliant knee clearance and non-compliant clear floor space provided.	§902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5E	Bench is 18.5" (470 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.58
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5F	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	§802.2	Relocate wheelchair areas so as to provide different lines of sight and with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$602.40
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5F	There is no companion seat provided next to the wheelchair area.	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5F	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5F	lectern is mounted at 35" (889 mm) above the finished floor to the top.	§808.4ph	Provide lectern mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5F	The jury box or witness stand has a non-compliant clear floor space.	§808.3	Remove 2 chairs or provide 2 removable chairs in jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5F	Witness stand desk has a non-compliant 25.75" (654 mm) knee clearance.	§902.2	Provide witness stand desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5F	Court reporter's desk has a non-compliant 26" (660 mm) knee clearance.	§902.2	Provide court reporter's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5F	Manager's desk has a non-compliant 26" (660 mm) knee clearance.	§902.2	Provide manager's desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room in Courtroom No. 5F	The sloped area of the ramp encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Provide automatic door opener to comply the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,595.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Room No. T506	Maneuvering clearance on the pull side of the door is 15.25" (387 mm).	§404.2.4	Provide automatic door opener to comply the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,595.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 1A	Wheelchair area is not an integral part of the fixed seating plan in courtroom and/or there is no companion fixed seat next to the wheelchair area.	§221.2.1.1	Seating capacity in courtroom is #, provide at least (#) wheelchair spaces and companion seats in courtroom seating area that comply with §221 (See 2010 ADA Table 221.2.1.1, Number of Wheelchair Spaces in Assembly Areas)	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 1A	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 1A	Podium is mounted at 40" (1016 mm) above the finished floor to the top.	§808.4ph	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 1A	The counter at jury box is mounted at 36.5" (927 mm) above the finished floor to the top.	§808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	Brochure rack is mounted beyond required reach allowed for approach provided and is mounted at 60.5" (1537 mm) above the finished floor to the highest shelf.	§308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	B	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	Podium is mounted at 40" (1016 mm) above the finished floor to the top.	§808.4ph	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	The counter at jury box is mounted at 36" (914 mm) above the finished floor to the top.	N808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	Accessible route leading to jury box has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	Accessible route clerk and court reporter's desk has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1C	Permanent room identifying signage is mounted at 65.5" (1664 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1C	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1C	Podium is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4ph	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1C	The counter at jury box is mounted at 36.5" (757 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1C	Accessible route leading to jury stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1C	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1C	Accessible route leading to court reporter's desk has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1C	Accessible route leading to judge's bench has a vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom 1C (Right Side)	Bench is 19.5" (495 mm) deep.	\$903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	Doorway opening has a clear width of 31.5" (800 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	Council's desk is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide council's desk mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	The counter at jury box is mounted at 36.5" (927 mm) above the finished floor to the top.	N808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	Accessible route leading to jury box has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp or portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	The jury box or witness stand has a non-compliant clear floor space.	\$808.3	Rework jury box/witness stand to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	Jury box does not provide the required diameter wheelchair turnaround space.	\$304.3	Rework area to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space (2010 ADA Fig. 304.3.2).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	Accessible route leading to witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp or portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	Accessible route leading to court reporter's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp or portable ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 1D	The only means of access to the judge's bench is by stairs.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a lift or ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 1A	Wheelchair area is not an integral part of the fixed seating plan and does not provide a companion fixed seat next to the wheelchair area.	\$221.2.2	The seating capacity of the courtroom is approximately 60, provide at least (2) designated wheelchair spaces and companion seats in courtroom seating areas that comply with §221 (See 2010 ADA Table 221.2.1.1.Number of Wheelchair Spaces in Assembly Areas)	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 1A	Aisle side seat are not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 1A	There is no signage indicating that assistive listening systems are provided inside the court room.	\$703.7.2.4	Provide Assistive Listening System identified by a symbol indicating International Symbol of Access for Hearing Loss (2010 ADA Fig. 703.7.2.4).	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 1A	Doorway opening has a clear width of 27" (686 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 1A	The fold down table at jury box is mounted at 37" (940 mm) above the finished floor to the top.	\$808.4	Replace fold down table and provide at least one accessible fold down table mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 1A	TV rack protrudes into walkway, projecting from back wall, and is mounted at 66" (1676 mm) above the finished floor to its bottom leading edge.	\$307.2a	Relocate and mount TV rack at or above 80" (2032 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	B	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2B	Wheelchair area is not an integral part of the fixed seating plan in courtroom and/or there is no companion fixed seat next to the wheelchair area.	\$221.2.1.1	Seating capacity in courtroom is 60, provide at least (2) wheelchair spaces and companion seats in courtroom seating area that comply with §221 (See 2010 ADA Table 221.2.1.1.Number of Wheelchair Spaces in Assembly Areas)	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2B	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2B	Doorway opening has a clear width of 28" (711 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2B	Podium is mounted at 40" (1016 mm) above the finished floor to the top.	\$808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2B	The fold down table at jury box is mounted at 37" (940 mm) above the finished floor to the top.	N808.4	Provide at least one accessible fold down table mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2C	Wheelchair area is not an integral part of the fixed seating plan in courtroom and/or there is no companion fixed seat next to the wheelchair area.	\$221.2.1.1	Seating capacity in courtroom is 60, provide at least (2) wheelchair spaces and companion seats in courtroom seating area that comply with §221 (See 2010 ADA Table 221.2.1.1.Number of Wheelchair Spaces in Assembly Areas)	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2C	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2C	Doorway opening has a clear width of 28" (711 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2C	Podium is mounted at 40" (1016 mm) above the finished floor to the top.	\$808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2C	The fold down table at jury box is mounted at 37.5" (952 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible fold down table mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2C	TV protrudes into walkway, projecting 11.5" (292 mm) from back wall, and is mounted at 67.5" (1714 mm) above the finished floor to its bottom leading edge.	\$307.2a	Relocate and mount TV at or above 80" (2032 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	B	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2D	Wheelchair area is not an integral part of the fixed seating plan in courtroom and/or there is no companion fixed seat next to the wheelchair area.	\$221.2.1.1	Seating capacity in courtroom is #, provide at least (#) wheelchair spaces and companion seats in courtroom seating area that comply with §221 (See 2010 ADA Table 221.2.1.1.Number of Wheelchair Spaces in Assembly Areas)	B	\$640.44

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2D	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2D	Podium is mounted at 40" (1016 mm) above the finished floor to the top.	§808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2D	The fold down table at jury box is mounted at 37.25" (946 mm) above the finished floor to the top.	§808.4	Provide at least one accessible fold down table mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2D	TV protrudes into walkway, projecting 13.25" (337 mm) from back wall, and is mounted at 71" (1803 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate and mount TV at or above 80" (2032 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	B	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	Wheelchair area is not an integral part of the fixed seating plan in courtroom and/or there is no companion fixed seat next to the wheelchair area.	§221.2.1.1	Seating capacity in courtroom is #, provide at least (#) wheelchair spaces and companion seats in courtroom seating area that comply with §221 (See 2010 ADA Table 221.2.1.1 Number of Wheelchair Spaces in Assembly Areas)	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	Doorway opening has a clear width of 28" (711 mm) on each active leaf.	§404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	Podium is mounted at 40" (1016 mm) above the finished floor to the top.	§808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	The fold down table at jury box is mounted at 37" (940 mm) above the finished floor to the top.	N808.4	Provide at least one accessible fold down table mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	TV protrudes into walkway, projecting 14" (356 mm) from back wall, and is mounted at 69" (1753 mm) above the finished floor to its bottom leading edge.	§307.2a	Relocate and mount TV at or above 80" (2032 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	B	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2F	Wheelchair area is not an integral part of the fixed seating plan in courtroom and/or there is no companion fixed seat next to the wheelchair area.	§221.2.1.1	Seating capacity in courtroom is 60, provide at least (2) wheelchair spaces and companion seats in courtroom seating area that comply with §221 (See 2010 ADA Table 221.2.1.1 Number of Wheelchair Spaces in Assembly Areas)	B	\$640.44
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2F	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2F	The fold down table at jury box is mounted at 36.5" (927 mm) above the finished floor to the top.	N808.4	Provide at least one accessible fold down table mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2F	TV protrudes into walkway, projecting 6" (152 mm) from back wall, and is mounted at 72" (1829 mm) above the finished floor to its bottom leading edge.	§307.2a	Relocate and mount TV at or above 80" (2032 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	B	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Main Entrance to Court House	The only means of access to the courthouse is by stairs.	§403.3	Provide an alternative accessible location or mitigate condition by means of a ramp, elevator or platform lift.	B	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Main Entrance to Court House	This entrance is inaccessible and does not have signage posted indicating the location of an accessible entrance.	§216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Main Entrance to Building	There is no signage posted indicating the location of an accessible entrance to this building.	§216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Main Entrance to Building	Accessible entrance has signage displaying the international symbol of accessibility but uses the derogatory term handicap entrance.	§216.6	Provide new signage at accessible entrance displaying the International symbol of accessibility indicating that this is the "Accessible Entrance"	B	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Main Entrance to Building	After hours button is mounted beyond required reach allowed for approach provided and is mounted at 57" (1448 mm) above the finished floor.	§308.2.1	Lower or install after hours button at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	B	\$395.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Main Entrance to Building	Mats are not securely attached to the floor.	§302.2	Provide securely attached mats with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	B	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	TV protrudes into walkway, projecting 4" (102 mm) from back wall, and is mounted below 80" (2032 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Holding Cells in Courtroom No. 8B	Maneuvering clearance on the pull side of the door is 8" (203 mm).	§404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 8B	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 8B	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 8B	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 8B	Lavatory does not provide the required knee clearance.	§606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 8B	Water closet encroaches over lavatory clear floor space.	§606.2	Install a wall hung lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 8B	Partition encroaches over the water closet clearance reducing it to 40.5"	§604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 8B	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 8B	Lavatory mirror is mounted at 41" (1041 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	TV protrudes into walkway, projecting more than 4" (102 mm) from back wall, and is mounted at less than 80" (2032 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate and mount TV at or above 80" (2032 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms at Jury Deliberation Room in Courtroom No. 8A	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,713.43

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms at Jury Deliberation Room in Courtroom No. 8A	Counter surface is mounted at 40" (1016 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Right side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Right side)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Right side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Water closet is centered at 18.75" (476 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Toilet seat cover dispenser is mounted 6" (152 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 56" (1422 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Counter at Warrant Service Division	Chairs encroach over maneuvering clearance on the pull side of the door reducing it to 8.5" (215 mm)	§404.2.4	Relocate chairs to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Unisex Accessible Restrooms in Front of Courtroom No. 8B	Drinking fountain spout outlet (orifice height) is mounted at a non-compliant height above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,173.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Toilet tissue dispenser is mounted 3" (76 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lb.	C	\$291.64
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 49" (1245 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Toilet tissue dispenser is mounted 3" (76 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Toilet seat cover dispenser is mounted beyond reach ranges at 54" (1372 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Counter surface is mounted at 34.5" (876 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 49" (1245 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor by Elevator's	AED protrudes into walkway, projecting 4.25" (108 mm) from back wall, and is mounted at 33" (838 mm) above the finished floor to its bottom leading edge.	§307.2r	Relocate or recess AED so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Unisex Accessible Restrooms Between Courtrooms E and F	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,173.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Accessible toilet compartment (stall) is 37.5" by 66" (952 by 1676 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Toilet tissue dispenser is mounted 3.5" (89 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Toilet seat cover dispenser is mounted beyond reach ranges at 54" (1372 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Water closet is centered at 19.5" (495 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Lavatory has partially unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 50.5" (1283 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T8029	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T8029	Toilet tissue dispenser is mounted 3" (76 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T8029	Water closet is centered at 20" (508 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T8029	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T8029	Toilet seat cover dispenser is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T8029	Sink is mounted at 34.75" (883 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Lactation Room	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Vending Machines	Vending machine control is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor.	§308.2.1	Lower or install vending machine controls at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Computer Room	Desk has a non-compliant 25.25" (637 mm) knee clearance to key board	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Computer Room	Desk encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate desk to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Selection Room Waiting Area	TVs protrude into walkway, projecting 6.5" (165 mm) from back wall, and is mounted at 69" (1753 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate or recess TVs so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Kitchenette at Lounge Area	TV protrudes into walkway, projecting 6.5" (165 mm) from back wall, and is mounted at 51.5" (1308 mm) above the finished floor to its bottom leading edge.	§307.2r	Relocate or recess TV so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	T700 Learning Center	Desk encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate desk to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7028	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7028	Accessible toilet compartment (stall) is 37.5" by 66" (952 by 1676 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7028	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7028	Toilet tissue dispenser is mounted 3.5" (89 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7028	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 60" (1524 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7028	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7028	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7027	Accessible toilet compartment (stall) is 37.5" by 67" (952 by 1702 mm) deep and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7027	Toilet tissue dispenser is mounted 2" (51 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7027	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7027	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7027	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.25" (1505 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7027	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor by Family Law Education Center	AED protrudes into walkway, projecting 4.5" (114 mm) from back wall, and is mounted at 32.5" (826 mm) above the finished floor to its bottom leading edge.	\$307.2	Relocate or recess AED so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Women's Accessible Restrooms No. T7026	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,713.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7026	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7026	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7026	Accessible toilet compartment (stall) is 37.5" by 66" (952 by 1676 mm) deep and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7026	Toilet tissue dispenser is mounted 3" (76 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7026	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7026	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7026	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7026	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7026	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7026	Toilet tissue dispenser is mounted 3.5" (89 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7026	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7026	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.25" (1505 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7026	Lavatory is mounted at 34.75" (883 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7026	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Public Defenders Office No. T519	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$291.64
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5B	Water closet is centered at 19.75" (502 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5B	Toilet tissue dispenser is mounted at a non-compliant distance in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5B	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5B	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 60" (1524 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5B	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5B	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5B	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	\$604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5B	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5B	Water closet is centered at 19.25" (489 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Toilet seat cover dispenser is mounted beyond reach ranges at 51" (1295 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5B	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 60" (1524 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5B	Urinal is mounted in a 34" (864 mm) alcove.	§605.3	Remove/relocate partitions to provide a 36" (914 mm) min. wide alcove for a forward approach to object (2010 ADA Fig. 305.7.1).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5B	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5B	Lavatory has partially unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Courtroom No. 5F	Drinking fountain spout outlet (orifice height) is mounted at 26.5" (673 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Water closet side wall grab bar is mounted at 53" (1346 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Water closet is centered at 19" (483 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Toilet seat cover dispenser is mounted beyond reach ranges at 51" (1295 mm) above the finished floor	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	The stall door is located at 7" (178 mm) from the side wall or partition farthest from the water closet	§604.8.1.2	Stall must provide a door with the opening mounted at 4" max. from the side wall or partition farthest from the water closet.	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 60" (1524 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Sanitary napkin and tampon dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor.	§308.2.1	Lower or install sanitary napkin and tampon dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 5F	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5F	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5F	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5F	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5F	Accessible toilet compartment (stall) door is located at 7" (178 mm) from the side wall or partition farthest from the water closet	§604.8.1.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (2010 ADA Fig. 604.8.1.1)	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5F	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 60.5" (1537 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5F	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 5F	Paper towel dispenser protrudes into walkway, projecting 4" (102 mm) from back wall, and is mounted at 4" (102 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4B	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4B	Toilet tissue dispenser is mounted 3" (76 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4B	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4B	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4B	Counter surface is mounted at 34.75" (883 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4B	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4B	Lavatory has partially unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4B	Accessible toilet compartment (stall) is 37.5" by 66" (952 by 1676 mm) deep and is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4B	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4B	Toilet tissue dispenser is mounted 2" (51 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4B	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4B	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.75" (1492 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4B	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4B	Lavatory is mounted at 34.75" (883 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Courtroom No.4F	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Accessible toilet compartment (stall) is 37.25" by 66" (946 by 1676 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Toilet tissue dispenser is mounted 5.75" (146 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Counter surface is mounted at 34.5" (876 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4F	Lavatory has partially unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4F	Accessible toilet compartment (stall) is 37.25" by 66" (946 by 1676 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4F	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4F	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4F	Toilet tissue dispenser is mounted 3.5" (89 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4F	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4F	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms in Front of Courtroom No. 4F	Lavatory has partially unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4F	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4F	Counter surface is mounted at 39.5" (1003 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Right side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Right side)	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Right side)	Toilet seat cover dispenser is mounted 4" (102 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Right side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Right side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54.5" (1384 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Left side)	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Left side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Left side)	Toilet seat cover dispenser is mounted 6.5" (165 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Left side)	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Left side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No.1 for Courtroom No. 4E	Holding cell bench is 19" (483 mm) deep	\$807.2.2	Replace/rework to provide a bench fixed to a wall that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep, with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface.	C	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No.3 for Courtroom No. 4E	Holding cell bench is 19.5" (495 mm) deep.	\$807.2.2	Replace/rework to provide a bench fixed to a wall that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep, with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface.	C	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No.3 for Courtroom No. 4E	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No.3 for Courtroom No. 4E	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No.3 for Courtroom No. 4E	Toilet tissue dispenser is mounted behind the front edge of the water closet.	\$604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No.3 for Courtroom No. 4E	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No.3 for Courtroom No. 4E	Water closet seat is mounted at 15" (381 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No.3 for Courtroom No. 4E	Partition encroaches over the water closet clearance reducing it to 40.75"	\$604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E	Counter surface is mounted at 39.5" (1003 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Toilet seat cover dispenser is mounted beyond reach ranges at 50" (1270 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Toilet seat cover dispenser is mounted 8" (203 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 12" (305 mm)	§404.2.4	Install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$545.58
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object. Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Left side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Left side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Left side)	Toilet seat cover dispenser is mounted 7.5" (190 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Left side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Left side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 12" (305 mm)	§404.2.4	Install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$545.58
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Left side)	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Courtroom No. 4D	Holding cell bench is 19.5" (495 mm) deep.	§807.2.2	Replace/rework to provide a bench fixed to a wall that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep, with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface.	C	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Courtroom No. 4D	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Courtroom No. 4D	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Courtroom No. 4D	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Courtroom No. 4D	Lavatory does not provide the required knee clearance.	§606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Courtroom No. 4D	Partition encroaches over the water closet clearance reducing it to 41"	§604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Courtroom No. 4D	Water closet seat is mounted at 15" (381 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,173.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D	Counter surface is mounted at 39" (991 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	Water closet side wall grab bar is mounted at 51" (1295 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	Toilet seat cover dispenser is mounted 5" (127 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 14" (356 mm)	§404.2.4	Install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object. Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Left Side)	No emergency visual notification device in room.	§702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	C	\$278.36

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	Water closet is centered at 18." (457 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	Toilet seat cover dispenser is mounted 3.25" (83 mm) over the side wall grab bar.	\$609.4	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	Lavatory is mounted at 34.75" (883 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 14" (356 mm)	\$404.2.4	Install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4D (Right Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	C	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,173.86
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C	Counter surface is mounted at 39.5" (1003 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Left Side)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Left Side)	Toilet seat cover dispenser is mounted 3.5" (89 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Left Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Left Side)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Left Side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Left Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	C	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Right Side)	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Right Side)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Right Side)	Toilet seat cover dispenser is mounted 4.25" (108 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Right Side)	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Right Side)	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room at Courtroom No. 4C (Right Side)	No emergency visual notification device in room.	\$702.1	Replace existing single station audible alarm with a combo unit to provide the visual and audible alarm notification. System shall be designed and installed in accordance with NFPA 72.	C	\$278.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Restrooms in Jury Deliberation Room at Courtroom No. 3A	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in Jury Deliberation Room at Courtroom No. 3A	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in Jury Deliberation Room at Courtroom No. 3A	Counter surface is mounted at 39.5" (1003 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Toilet tissue dispenser is mounted at 16" (406 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 56.5" (1435 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure figure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 49" (1245 mm) above the finished floor.	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Doorway has a 0.5" (13 mm) vertical change of level at door threshold.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Right Side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Left Side)	Toilet tissue dispenser is mounted at 18" (457 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Left Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 56" (1422 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Left Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure figure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Left Side)	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms in Jury Deliberation Room at Courtroom No. 3A (Left Side)	Chair encroaches over trash bin and paper towel dispenser clear floor space.	\$305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at trash bin and at paper towel dispenser (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3A	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3A	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3A	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3A	Toilet tissue dispenser is mounted behind the front edge of the water closet.	\$604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3A	Water closet encroaches over lavatory clear floor space.	\$606.2	Provide a wall hung lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$1,015.96
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3A	Partition encroaches over the water closet clearance reducing it to 41" (1041 mm)	\$604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3A	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in jury Deliberation Room at Courtroom No. 3B	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in jury Deliberation Room at Courtroom No. 3B	Counter surface is mounted at 39.5" (1003 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Toilet tissue dispenser is mounted at 12.5" (318 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Toilet seat cover dispenser is mounted beyond reach ranges at 55.25" (1403 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15' to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 50.25" (1276 mm) above the finished floor	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Toilet tissue dispenser is mounted at 17" (432 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Toilet seat cover dispenser is mounted beyond reach ranges at 54" (1372 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15' to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3B	Chair encroaches over trash bin and paper towel dispenser clear floor space.	\$305.3	Relocate trash bin and paper towel dispenser to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Restrooms in jury Deliberation Room at Courtroom No. 3D	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in jury Deliberation Room at Courtroom No. 3D	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in jury Deliberation Room at Courtroom No. 3D	Counter surface is mounted at 39.5" (1003 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 53.5" (1359 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15' to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Toilet seat cover dispenser is mounted 11.25" (286 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 14" (356 mm)	\$404.2.4	Provide a smaller size lavatory that allows the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Right Side)	Chair encroaches over trash bin and paper towel dispenser clear floor space.	\$305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 54" (1372 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Toilet seat cover dispenser is mounted 11.5" (292 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.5" (1334 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom in jury Deliberation Room at Courtroom No. 3D (Left Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 14" (356 mm)	\$404.2.4	Install a smaller size lavatory that allows the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.96
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Partition encroaches over the water closet clearance reducing it to 40.75"	\$604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Toilet tissue dispenser is mounted behind the front edge of the water closet.	\$604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Water closet encroaches over lavatory clear floor space.	\$606.2	Install a lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2 at Courtroom No. 3D	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in jury Deliberation Room at Courtroom No. 3E Corridor Leading to Restrooms in jury Deliberation Room at Courtroom No. 3E	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in jury Deliberation Room at Courtroom No. 3E	Counter surface is mounted at 39" (1003 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Toilet tissue dispenser is mounted at 12" (305 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 55.5" (1409 mm) above the finished floor	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 11.5" (292 mm)	\$404.2.4	Install a smaller size lavatory that allows the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54.5" (1384 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Right Side)	Trash bin encroaches over paper towel dispenser clear floor space.	\$305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Left Side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Left Side)	Toilet tissue dispenser is mounted at a non-compliant distance in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Left Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Left Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Left Side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Left Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 11.5" (293 mm)	§404.2.4	Install a smaller size lavatory that provides the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3E (Left Side)	Trash bin encroaches over paper towel dispenser clear floor space.	§305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in jury Deliberation Room at Courtroom No. 3F	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.33
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Right Side)	Counter surface is mounted at 40" (1016 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Right Side)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Right Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Right Side)	Lavatory is mounted at 34.75" (883 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Right Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 55.5" (1410 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Right Side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Right Side)	Chair encroaches over trash bin and paper towel dispenser clear floor space.	§305.3	Relocate trash bin and paper towel dispenser to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Left Side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Left Side)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Left Side)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Left Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Left Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56" (1422 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in jury Deliberation Room at Courtroom No. 3F (Left Side)	Doorway has a vertical change of level at door threshold that is not beveled.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3F	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3F	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3F	Water closet encroaches over lavatory clear floor space.	§606.2	Install a new lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3F	Partition encroaches over the water closet clearance reducing it to 40.75"	§604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$600.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3F	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 3F	Lavatory does not provide the required knee clearance.	§606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Restroom between Courtrooms 3E and 3F (Right Side)	Door has a non-compliant opening force of 10 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Restroom between Courtrooms 3E and 3F (Right Side)	Accessible toilet compartment (stall) is 37" (940 mm) wide by 66"(1677 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Restroom between Courtrooms 3E and 3F (Right Side)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Restroom between Courtrooms 3E and 3F (Right Side)	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Restroom between Courtrooms 3E and 3F (Right Side)	Toilet seat cover dispenser is mounted 3" (76 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Restroom between Courtrooms 3E and 3F (Right Side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Restroom between Courtrooms 3E and 3F (Right Side)	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Restroom between Courtrooms 3E and 3F (Right Side)	Lavatory has partially unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Room No. TG100 (State Court civil Division)	Computer work station counter surface is mounted at 40" (1016 mm) above the finished floor.	§902.3	Rework to provide the top of the computer work station counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Records	Counter is mounted at 40.5" (1029 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Criminal Warrants	Counter is mounted at 41.5" (1054 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Customer Service	Counter is mounted at 40.75" (1035 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Real estate Recording Room No. TG200	Counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Real estate Recording Room No. TG200	Work station counter surface is mounted at 40.5" (1029 mm) above the finished floor.	§902.3	Rework to provide the top of the work station counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to JCT County Courthouse	Ramp has a non-compliant surface slope of up to 8.8 %.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%. Per ADA section 4.1.6 (j) it is technically infeasible to alter the ramp as the changes have little likelihood of being accomplished.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to JCT County Courthouse	Ramp handrails are mounted at 29.75" (756 mm) above the finished floor to top of gripping surfaces.	§4.8	Install handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the finished floor to top of gripping surfaces. Handrails shall extend 12" (304 mm) min. beyond the top and bottom of the ramp segment. Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$9,960.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Estate and Magistrate Court Self Help Center TG300	Counter is mounted at 44" (1118 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Magistrate Court Dispossessionary	Counter is mounted at 40.75" (1035 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Treasury Court Administration	Counter is mounted at 40.75" (1035 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Counter at Small Claims	Counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). An ADA accessible table has been provided in the same area, no remedial work is necessary.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to Fulton County Court House	First leg of the ramp has a non-compliant surface slope of 9.5 %.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%. Per ADA section 4.1.6 (j) it is technically infeasible to alter the ramp as the changes have little likelihood of being accomplished.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to Fulton County Court House	Ramp handrails are mounted at 30" (762 mm) above the finished floor to the top of the gripping surface.	§405.8	Install handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the finished floor to top of gripping surfaces. Handrails shall extend 12" (304 mm) min. beyond the top and bottom of the ramp segment. Element compliant with UFAS standards, no remedial work is necessary	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to Fulton County Court House	Second portion of the ramp has a non-compliant surface slope of 8.6 %.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%. For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to Fulton County Court House	Second leg of the ramp handrails are mounted at 30" (762 mm) above the finished floor.	§405.8	Install handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the finished floor to top of gripping surfaces. Handrails shall extend 12" (304 mm) min. beyond the top and bottom of the ramp segment. Element compliant with UFAS standards, no remedial work is necessary	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Ramp Leading to Fulton County Court House	Third leg of the ramp handrails are mounted at 30" (762 mm) above the finished floor.	\$405.8	Install handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the finished floor to top of gripping surfaces. Handrails shall extend 12" (304 mm) min. beyond the top and bottom of the ramp segment. Element compliant with UFAS standards, no remedial work is necessary	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor in jury Deliberation Room at Courtroom No. 7E	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,173.13
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Toilet tissue dispenser is mounted at 12.5" (318 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 50.5" (1283 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Toilet seat cover dispenser is mounted 9" (229 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 51.25" (1302 mm) above the finished floor.	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 11.5" (293 mm)	\$404.2.4	Install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Right Side)	Doorway has a non-compliant vertical change of level at door threshold that is not beveled.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Left Side)	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Left Side)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Left Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 50" (1270 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Left Side)	Toilet seat cover dispenser is mounted 8" (203 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7E (Left Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 11.5" (293 mm)	\$404.2.4	Relocate encroaching item to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 7E	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 7E	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 7E	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 7E	Toilet tissue dispenser is mounted behind the front edge of the water closet.	\$604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 7E	Water closet encroaches over lavatory clear floor space.	\$606.2	Install a new lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 7E	Partition encroaches over the water closet clearance reducing it to 41"	\$604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 7E	Water closet seat is mounted at 14" (356 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor in jury Deliberation Room at Courtroom No. 7F	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,173.36

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor in jury Deliberation Room at Courtroom No. 7F	Counter surface is mounted at 40" (1016 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Left Side)	Lavatory is mounted at 30.75" (781 mm) from water closet side wall to outer leading edge of lavatory.	§4.19	Relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading edge of lavatory.	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Left Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 55.25" (1403 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Left Side)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Left Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 52" (1321 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	Toilet seat cover dispenser is mounted 10.25" (260 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56" (1422 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in jury Deliberation Room at Courtroom No. 7F (Right Side)	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADA/AG Fig. 303.3).	C	\$137.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor by Jury Room No. t5A04	Drinking fountain is mounted in a 29.5" (749 mm) wide and 29.5" (749 mm) deep alcove.	§305.7.1	Rework partitions to provide a 30" (762 mm) min. wide alcove for a forward approach to object (2010 ADA Fig. 305.7.1).	C	\$3,173.37
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Paper towel dispenser is mounted at a non-compliant height over the rear wall grab bar.	§609.3	Relocate paper towel dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Lavatory encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Install a smaller size lavatory that allows the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Water closet is centered at 19" (483 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Sink is mounted at 34.75" (883 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Lavatory encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Install a smaller size lavatory that allows the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Toilet seat cover dispenser is mounted at a non-compliant distance over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Paper towel dispenser is mounted at a non-compliant distance over the rear wall grab bar.	§609.3	Paper towel dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No. t5A04 (Right side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 64" (1626 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Lavatory does not provide the required knee clearance.	§606.2.2	Rework lavatory to provide the required 27" (695 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Water closet encroaches over lavatory clear floor space.	§606.2	Install a wall hung lavatory that provides provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Partition encroaches over the water closet clearance reducing it to 41"	§604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5A	Water closet seat is mounted at 14" (356 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor at Jury Room No.5B	Furniture encroaches over coat hook clear floor space.	§305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor at Jury Room No.5B	Drinking fountain spout outlet (orifice height) is mounted at 40" (1016 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,173.36
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Toilet seat cover dispenser is mounted beyond reach ranges at 50" (1270 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Toilet seat cover dispenser is mounted at a non-compliant height over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Paper towel dispenser is mounted at a non-compliant height over the rear wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the rear wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Water closet rear wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Right side)	Water closet side wall grab bar is mounted at 52" (1321 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Left side)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Left side)	Toilet seat cover dispenser is mounted at a non- compliant height over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Left side)	Paper towel dispenser is mounted at a non- compliant height over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the rear wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Left side)	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Left side)	Water closet side wall grab bar is mounted at 52" (1321 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Left side)	Lavatory is mounted at 34.75" (883 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom at Jury Room No.5B (Left side)	Water closet rear wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5C	Ramp has a non-compliant surface slope of 9.6 %.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5C	Ramp has a 48" (1219 mm) top landing.	§405.7.3	Rework ramp to provide 60" (1524 mm) min. long top landing for runs rising over 30" (762 mm) (2010 ADA Fig. 405.7).	C	\$4,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5C	Ramp does not have the required handrail extensions.	§405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A	C	\$360.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Entrance to Courtroom No. 5C	Maneuvering clearance on the pull side of the door is 42" (1067 mm) deep due to ramp run	§404.2.4	Provide an automatic door opener to comply with 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$1,595.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Water closet side wall grab bar is mounted at 53" (1346 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 13" (51 mm)	§404.2.4	Install a smaller size lavatory that will allow a 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Right Side)	Soap dispenser is mounted at a non-compliant height over the rear wall grab bar.	§609.3	Relocate soap dispenser to provide a clear space between the rear wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Left Side)	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Left Side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Left Side)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Left Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 12" (47 mm)	§404.2.4	Relocate encroaching item to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room No. T5C06 (Left Side)	Soap dispenser is mounted at a non-compliant height over the rear wall grab bar.	§609.3	Relocate toilet soap dispenser to provide a clear space between the rear wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1st Courtroom No. 5C	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1st Courtroom No. 5C	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1st Courtroom No. 5C	Lavatory does not provide the required knee clearance.	§606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1st Courtroom No. 5C	Partition encroaches over the water closet clearance reducing it to 40.5"	§604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1st Courtroom No. 5C	Water closet seat is mounted at 14" (356 mm) above the finished floor to top (single user)	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1st Courtroom No. 5C	Water closet encroaches over lavatory clear floor space.	§606.2	Relocate encroaching item to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1st Courtroom No. 5C	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor in Jury Room No. T5D03	Wall/post mounted drinking fountain does not provide the required knee clearance only has a parallel approach.	§602.1	Relocate/rework fountain to provide a 27" (685 mm) min. knee clearance above the finished floor, 30" (762 mm) min. wide and 25" (635 mm) max. deep (2010 ADA Fig. 306.3). Per 1990 ADA a parallel approach is allowed to the drinking fountain, no remedial work is necessary.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	Water closet is centered at 33" (838 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	Water closet side wall grab bar is mounted at 52" (1321 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	Toilet seat cover dispenser and paper towel dispenser are mounted at a non-compliant height over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser and paper towel dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	Chair encroaches over the water closet clearance.	§604.3.2	Remove / relocate chair to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	Sink is mounted at 35" (889 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Left Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Reverse door swing or install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area.	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Water closet is centered at 36.5" (927 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Water closet side wall grab bar is mounted at 53" (1346 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Toilet seat cover dispenser and paper towel dispenser are mounted at a non-compliant height over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser and paper towel dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Chair encroaches over the water closet clearance.	§604.3.2	Relocate chair to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T5D03 (Right Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Reverse door swing or install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area.	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Courtroom No. 5D	Maneuvering clearance on the push side of the door is 6" (152 mm).	§404.2.4	Remove door closer to comply with the required 12" (304 mm) min. maneuvering clearance on the push side of the door handle side beyond the latch and 48" (1219 mm) min. deep clear floor area (For doors with latch and closer) (2010 ADA Fig. 404.2.4.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain in Jury Room in No. T5E05	Wall/post mounted drinking fountain does not provide the required knee clearance only has a parallel approach.	§602.1	Relocate/rework fountain to provide a 27" (685 mm) min. knee clearance above the finished floor, 30" (762 mm) min. wide and 25" (635 mm) max. deep (2010 ADA Fig. 306.3). Per 1990 ADA a parallel approach is allowed to the drinking fountain, no remedial work is necessary.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Right side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Right side)	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Right side)	Water closet side wall grab bar is mounted at 52" (1321 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Right side)	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Right side)	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Right side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Right side)	Paper towel dispenser and soap dispenser are mounted at a non-compliant height over the rear wall grab bar.	§609.3	Relocate paper towel dispenser and soap dispenser to provide a clear space between the rear wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Right side)	Lavatory encroaches over deep maneuvering clearance on the pull side of the door reducing it to 46" (1.81 mm)	§404.2.4	Provide an automatic door opener to comply with the requirements for 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area	C	\$1,595.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Lavatory encroaches over deep maneuvering clearance on the pull side of the door reducing it to 46" (1.81 mm)	§404.2.4	Provide an automatic door opener to comply with the requirements for 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area	C	\$1,595.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Water closet side wall grab bar is mounted at 52" (1321 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Paper towel dispenser is mounted at a non-compliant height over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Water closet is centered at 19" (483 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room in No. T5E05 (Left side)	Lavatory encroaches over deep maneuvering clearance on the pull side of the door reducing it to 46" (1.81 mm)	§404.2.4	Provide an automatic door opener to comply with the requirements for 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5E	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5E	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5E	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5E	Lavatory does not provide the required knee clearance.	§606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5E	Water closet encroaches over lavatory clear floor space.	§606.2	Install a wall hung lavatory that provides 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5E	Partition encroaches over the water closet clearance reducing it to 40.5"	§604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 at Courtroom No. 5E	Water closet seat is mounted at 14" (356 mm) above the finished floor to top (single user)	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Water closet side wall grab bar is mounted at 53" (1346 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Left Side)	Soap dispenser is mounted at a non-compliant height over the rear wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the rear wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Right Side)	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Right Side)	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	\$604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Right Side)	Water closet side wall grab bar is mounted at 53" (1346 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Right Side)	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Right Side)	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Right Side)	Lavatory encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Install a smaller size lavatory that will allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area.	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Room No. T506 (Right Side)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 64" (1626 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Maneuvering clearance on the pull side is 41" (1041 mm) wide for a parallel latch approach.	\$404.2.4	Rework stall partition to provide the required 42" (1065 mm) min. maneuvering clearance on the pull side of the door, for a parallel latch (2010 ADA Fig. 604.8.1.2)	C	\$1,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Accessible toilet compartment (stall) is 37"(940 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (For children's water closet) (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Toilet tissue dispenser is mounted 4.25" (108 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.75" (1518 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Counter surface is mounted at 34.75" (883 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom 3E and 3 F (RESTROOM WAS PENDING SURVEY)	Lavatory outside the stall has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Accessible toilet compartment (stall) is 37"(940 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Toilet tissue dispenser is mounted 2.5" (64 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Toilet tissue dispenser is mounted at 13.5" (343 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No. 3T015 (Between Courtroom 3B and 3C)	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor by Courtroom No. 2C	AED protrudes into walkway, projecting 4.5" (114 mm) from back wall, and is mounted at 33.5" (851 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess AED so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$371.02
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2C and 2D	Accessible toilet compartment (stall) is 37"(940 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2C and 2D	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2C and 2D	Toilet tissue dispenser is mounted 3" (76 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2C and 2D	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2C and 2D	Toilet tissue dispenser is mounted at 13.5" (343 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2C and 2D	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2C and 2D	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2C and 2D	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No. T2012 (Between Courtroom No. 2C and 2D)	Accessible toilet compartment (stall) is 37"(940 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No. T2012 (Between Courtroom No. 2C and 2D)	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No. T2012 (Between Courtroom No. 2C and 2D)	Toilet seat cover dispenser and toilet tissue dispenser are mounted 3.5" (89 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser and toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No. T2012 (Between Courtroom No. 2C and 2D)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No. T2012 (Between Courtroom No. 2C and 2D)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No. T2012 (Between Courtroom No. 2C and 2D)	Counter surface is mounted at 34.5" (876 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No. T2012 (Between Courtroom No. 2C and 2D)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Between Courtroom No. 2E and 2F	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Accessible toilet compartment (stall) is 37"(940 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Toilet tissue dispenser is mounted 4.5" (114 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Toilet tissue dispenser is mounted at 13" (330 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Water closet is centered at 20.5" (521 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom Between Courtroom No. 2E and 2F	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). No remedial work is necessary. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lb.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Accessible toilet compartment (stall) is 37"(940 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Toilet tissue dispenser is mounted 3" (76 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Water closet is centered at 19.5" (495 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Counter surface is mounted at 34.5" (876 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom Between Courtroom No. 2E and 2F	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). No remedial work is necessary. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No. 1B and 1C)	Accessible toilet compartment (stall) is 37"(940 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No. 1B and 1C)	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No.1B and 1C)	Toilet tissue dispenser is mounted 6" (152 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No.1B and 1C)	Toilet tissue dispenser is mounted at 13" (330 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No.1B and 1C)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 56.25" (1429 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No.1B and 1C)	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No.1B and 1C)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No.1B and 1C)	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom T100T (Between Courtroom No.1B and 1C)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). No remedial work is necessary. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom (Between Courtroom No.1B and 1C)	Accessible toilet compartment (stall) is 37"(940 mm) wide and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom (Between Courtroom No.1B and 1C)	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom (Between Courtroom No.1B and 1C)	Toilet tissue dispenser is mounted 3" (76 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom (Between Courtroom No.1B and 1C)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom (Between Courtroom No.1B and 1C)	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 1A	Accessible route leading to witness stand has a 5" (127 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	C	\$271.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 1A	Accessible route leading to court reporter's station has a 5.5" (140 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	C	\$463.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain at Jury Deliberation Room in Courtroom No. 1A	Chairs encroaches over drinking fountain clear floor space.	§305.3	Relocate chairs to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain at Jury Deliberation Room in Courtroom No. 1A	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Left Side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Left Side)	Water closet is centered at 18.75" (476 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Left Side)	Toilet seat cover dispenser is mounted 10" (254 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Left Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Left Side)	Chair encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Left Side)	Restroom does not provide the required maneuvering clearance on the pull side.	§404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Right Side)	Chair encroaches over trash bin and hand dryer clear floor space.	§305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Right Side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Right Side)	Toilet tissue dispenser is mounted at 19" (483 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Right Side)	Toilet seat cover dispenser is mounted 9.5" (241 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 1A (Right Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3	Holding cell bench is 19.5" (495 mm) deep by 35" (889 mm) wide.	§807.2.2	Replace/rework to provide a bench fixed to a wall that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep, with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface to a point 18" (455 mm) min. above the seat surface bench must be mounted 17"-19" (431mm-485 mm) above the finished (2010 ADA Fig. 903.4).	C	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2	Holding cell bench is 19.5" (495 mm) deep by 35" (889 mm) wide.	§807.2.2	Replace/rework to provide a bench fixed to a wall that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep, with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface to a point 18" (455 mm) min. above the seat surface bench must be mounted 17"-19" (431mm-485 mm) above the finished (2010 ADA Fig. 903.4).	C	\$452.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2	Partition encroaches over the water closet clearance reducing it to 40" (1016 mm)	§604.3.2	Remove partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2	Water closet seat is mounted at 14" (356 mm) above the finished floor to top (single user)	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2	Lavatory does not provide the required knee clearance.	§606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 2	Water closet encroaches over lavatory clear floor space.	§606.2	Install a new lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$1,015.91
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom B	Brochure rack is mounted beyond required reach allowed for approach provided and is mounted at 60.5" (1537 mm) above the finished floor to the highest shelf.	§308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in Jury Deliberation Room at Courtroom B	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Right Side)	Toilet seat cover dispenser is mounted 8.5" (216 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Right Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Right Side)	Chair encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Right Side)	Lavatory encroaches over wide maneuvering clearance on the pull side of the door.	§404.2.4	Install a smaller lavatory to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor (2010 ADA Fig. 404.2.4.1).	C	\$1,015.86
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Left Side)	Toilet seat cover dispenser is mounted 9.5" (241 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Left Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom B (Left Side)	Maneuvering clearance on the pull side of the door is 16.5" (419 mm).	§4.13	Install a power door opener to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor area (ADAAG Fig. 25).	C	\$3,125.71
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in Jury Deliberation Room at Courtroom 1C	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1C (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1C (Left Side)	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1C (Left Side)	Toilet seat cover dispenser is mounted 9.5" (241 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1C (Left Side)	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1C (Left Side)	Chair encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1C (Right Side)	Toilet seat cover dispenser is mounted 11" (279 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1C (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom 1C (Right Side)	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom 1C (Right Side)	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom 1C (Right Side)	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom 1C (Right Side)	Water closet encroaches over lavatory clear floor space.	§606.2	Provide a lavatory that allows a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom 1C (Right Side)	Partition encroaches over the water closet clearance reducing it to 41.5" (1054 mm)	\$604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom 1C (Right Side)	Water closet seat is mounted at 14" (356 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 at Courtroom 1C (Right Side)	Lavatory does not provide the required knee clearance.	\$606.2.2	Install a new lavatory that provides the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in Jury Deliberation Room at Courtroom 1D	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Corridor Leading to Restrooms in Jury Deliberation Room at Courtroom 1D	Table encroaches passage width reducing it to 20" (508 mm).	\$403.5.1	Relocate table to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Left Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Left Side)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Left Side)	Toilet seat cover dispenser is mounted 1" (25 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Left Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Left Side)	Chair encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Left Side)	Lavatory encroaches over wide maneuvering clearance on the pull side of the door.	\$404.2.4	Install a smaller sink to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Right Side)	Maneuvering clearance on the push side of door is 20" (508 mm) wide for a parallel latch approach due to a table in the corridor.	\$404.2.4	Remove table from corridor to provide the required 24" (610 mm) min. maneuvering clearance on the push side of the door handle side beyond the latch and 42" (1065 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Right Side)	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Right Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Right Side)	Chair encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Remove chair from inside of restroom to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Right Side)	Water closet is centered at 20" (508 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Right Side)	Toilet tissue dispenser is mounted at a non- compliant distance in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom 1D (Right Side)	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Unisex Accessible Restrooms Between Courtrooms C and D	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms Between Courtrooms C and D	Toilet tissue dispenser is mounted at a non- compliant distance in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms Between Courtrooms C and D	Toilet tissue dispenser is mounted 4" (102 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms Between Courtrooms C and D	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms Between Courtrooms C and D	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms Between Courtrooms C and D	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms Between Courtrooms C and D (T1006)	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms Between Courtrooms C and D (T1006)	Toilet tissue dispenser is mounted at a non- compliant distance in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms Between Courtrooms C and D (T1006)	Toilet seat cover dispenser is mounted beyond reach ranges at 58" (1473 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms Between Courtrooms C and D (T1006)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms Between Courtrooms C and D (T1006)	The stall door is not located in partition or side wall farthest from water closet.	\$604.8.1.2	Rework stall partitions and provide stall door mounted in the front partition or in the side wall or partition farthest from the water closet.	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms Between Courtrooms C and D (T1006)	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms Between Courtrooms C and D (T1006)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Accessible Restrooms By Sheriff Department Accounting Division	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Accessible Restrooms By TG100	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Drinking Fountain by Accessible Restrooms By TG100	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No.TG003	Accessible toilet compartment (stall) is 37.5" (952 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No.TG003	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No.TG003	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No.TG003	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No.TG003	Toilet tissue dispenser is mounted at a non-compliant distance in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No.TG003	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restroom No.TG003	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No.TG004	Doorway has a 0.5" (13 mm) vertical change of level at door threshold.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.83
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No.TG004	Accessible toilet compartment (stall) is 37.5" (952 mm) wide and it is configured as an ambulatory stall.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No.TG004	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No.TG004	Toilet tissue dispenser is mounted 2" (51 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No.TG004	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58" (1473 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No.TG004	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No.TG004	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No.TG004	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.5" (1334 mm) above the finished floor.	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 1A	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 1A	Condiment counter surface is mounted at 39.5" (1003 mm) above the finished floor.	\$902.3	Rework to provide the top of the condiment counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 1A	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 1A	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.25" (1429 mm) above the finished floor	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 1A	Toilet seat cover dispenser mounted at 50.5" (1283 mm) above the finished floor.	\$308.2.1	Install toilet seat cover dispenser mounted 48" above the finished floor to the centerline of the outlet (2010 ADA Figs. 308.2.1, 308.2.2, 308.3.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 1A	Toilet seat cover dispenser is mounted 8.25" (210 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 1A	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 1A	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 1A	Lower coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object. Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 1A	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 1A	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 1A	Toilet seat cover dispenser is mounted beyond reach ranges at 52.5" (1334 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 1A	Toilet seat cover dispenser is mounted 10" (254 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 1A	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 1A	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 1A	Chair encroaches over paper towel dispenser and trash bin clear floor space clear floor space.	§305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Holding Cell in Court Room No. 1A	Maneuvering clearance on the pull side of the door is 6" (152 mm).	§404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 1A	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 1A	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 1A	Water closet encroaches into lavatory clear floor space.	§606.2	Install a wall hung lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 305).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 1A	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 1A	Partition encroaches over the water closet clearance reducing it to 41" (1041 mm)	§604.3.2	Remove partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 1A	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 1A	Lavatory does not provide the required knee clearance.	§606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Interview Room No. 1 in Courtroom No. 1A	Permanent room identifying signage does not have Braille or raised characters and is mounted at 64" (1626 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 2B	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 2B	Counter surface is mounted at 39.5" (1003 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2B	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2B	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2B	Toilet seat cover dispenser is mounted 9.75" (248 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2B	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54.5" (1384 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2B	Chair encroaches over trash bin and paper towel dispenser clear floor space.	§305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2B	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2B	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2B	Lavatory has partially unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2B	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2B	Toilet seat cover dispenser is mounted beyond reach ranges at 53.5" (1359 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2B	Toilet seat cover dispenser is mounted 9.75" (286 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2B	Toilet tissue dispenser is mounted at 36" (914 mm) from rear wall to outer leading edge.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2B	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 2C	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 2C	Counter surface is mounted at 38.25" (972 mm) above the finished floor to the top.	§902.3	Rework area to provide the top of the counter surface, mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2C	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2C	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2C	Toilet seat cover dispenser is mounted beyond reach ranges at 54" (1372 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2C	Toilet seat cover dispenser is mounted 9.75" (279 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2C	Toilet tissue dispenser is mounted at 9.5" (241 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2C	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2C	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2C	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2C	Toilet seat cover dispenser is mounted beyond reach ranges at 51.5" (1308 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2C	Toilet seat cover dispenser is mounted 9.5" (241 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2C	Toilet tissue dispenser is mounted at 9.5" (241 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2C	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.25" (1327 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Holding cell is 47" (1194 mm) wide and does not provide the required diameter wheelchair turnaround space due to the bench.	\$807.2.1	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space within the cell (2010 ADA Fig. 304.3.2).	C	\$3,796.01
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Water closet encroaches into lavatory clear floor space.	\$606.2	Install a wall hung lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 305).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Partition encroaches over the water closet clearance reducing it to 40.25" (1022 mm)	\$604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Water closet seat is mounted at 15" (381 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Toilet tissue dispenser is mounted behind the front edge of the water closet.	\$604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Court Room No. 2D	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Court Room No. 2D	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Court Room No. 2D	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Court Room No. 2D	Lavatory inside the stall has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Court Room No. 2D	Toilet seat cover dispenser is mounted beyond reach ranges at 49.5" (1257 mm) above the finished floor .	N308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Court Room No. 2D	Toilet seat cover dispenser is mounted 7.25" (185 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Court Room No. 2D	Chair encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	The only means of access to the witness stand is by stairs.	\$4.5.2	Mitigate condition by means of a ramp or platform lift.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	Accessible route leading to the witness stand has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	C	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2E	Accessible route leading to the jury box has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Court Room No. 2E	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Court Room No. 2E	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Court Room No. 2E	Water closet is centered at 19" (483 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Court Room No. 2E	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Court Room No. 2E	Toilet seat cover dispenser is mounted beyond reach ranges at 53.75" (1365 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Court Room No. 2E	Toilet seat cover dispenser is mounted 11.25" (286 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Accessible Route Leading to Holding Cell No. 1 in Court Room No. 2E	Maneuvering clearance on the pull side of the door is 7" (178 mm).	§404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2E	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADA Fig. 604.5.1).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2E	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2E	Water closet encroaches over lavatory clear floor space.	§606.2	Install a wall hung lavatory that provides a 30" by 48" (762 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 305).	C	\$1,015.16
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2E	Partition encroaches over the water closet clearance reducing it to 41.5"	§604.3.2	Remove / relocate partition to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2E	Toilet tissue dispenser is mounted behind the front edge of the water closet.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2E	Water closet seat is mounted at 14.5" (368 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2F	Accessible route leading to the jury box has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Court Room No. 2F	Accessible route leading to the witness stand has a 6" (152 mm) vertical change in level.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a portable ramp (2010 ADA Fig. 303.3).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 2F	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 2F	Counter surface is mounted at 40" (1016 mm) above the finished floor.	§902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Toilet seat cover dispenser is mounted beyond reach ranges at 54" (1372 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Toilet seat cover dispenser is mounted 11.5" (292 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Toilet tissue dispenser is mounted at 34.5" (876 mm) from rear wall to outer leading edge.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54.5" (1384 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Water closet is centered at 18.25" (464 mm) from side wall	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Toilet seat cover dispenser is mounted beyond reach ranges at 51.5" (1308 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Toilet seat cover dispenser is mounted 9.5" (241 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54.5" (1384 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Counter surface is mounted at 39.75" (1010 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2E	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2E	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2E	Toilet seat cover dispenser is mounted beyond reach ranges at 52" (1321 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2E	Toilet seat cover dispenser is mounted 9.5" (241 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2E	Toilet tissue dispenser is mounted at 36" (914 mm) from rear wall to outer leading edge.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2E	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 14" (356 mm)	\$404.2.4	Relocate lavatory to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$1,015.91
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Water closet is centered at 18.75" (476 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Toilet seat cover dispenser is mounted beyond reach ranges at 51.5" (1308 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Toilet seat cover dispenser is mounted 9" (229 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Toilet tissue dispenser is mounted at 11.5" (292 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.5" (1334 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2E	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 13" (330 mm)	\$404.2.4	Relocate lavatory to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$1,015.91
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Jury Deliberation Room in Court Room No. 2D	Drinking fountain spout outlet (orifice height) is mounted at 42" (1067 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$3,137.43
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303		Counter surface is mounted at 39.5" (1003 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Water closet side wall grab bar is mounted at 52" (1321 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1) Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$150.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Toilet seat cover dispenser is mounted 4" (102 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Toilet tissue dispenser is mounted at 36" (914 mm) from rear wall to outer leading edge.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Left Side) at Jury Deliberation Room in Court Room No. 2f	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 11" (279 mm)	§404.2.4	Relocate lavatory to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$1,015.91
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Toilet seat cover dispenser is mounted 6.25" (159 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2f	Lavatory encroaches over maneuvering clearance on the pull side of the door reducing it to 17" (432 mm)	§404.2.4	Relocate lavatory to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$1,015.91
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Elevator 14	Elevator door reopening device causes elevator doors to remain open for 16 seconds.	§407.3.3	Adjust elevator door reopening device to remain open for at least 20 seconds.	C	\$398.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Elevator 15	Elevator door reopening devices remain open for 17 seconds.	§407.3.3	Provide an elevator door reopening device that remains open for at least 20 seconds and senses an obstruction passing through the opening between 5" - 29" (127 mm - 736 mm) min above the finished floor.	C	\$398.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Elevator 16	Elevator door reopening devices remain open for 12 seconds.	§407.3.3	Provide an elevator door reopening device that remains open for at least 20 seconds and senses an obstruction passing through the opening between 5" - 29" (127 mm - 736 mm) min above the finished floor.	C	\$398.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Connector From Building No. 160 to Building No. 141	Ramp handrails do not have extensions.	§405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A	C	\$380.20
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Elevator 14	Elevator door reopening device causes elevator doors to remain open for 16 seconds.	§407.3.3	Adjust elevator door reopening device to remain open for at least 20 seconds.	C	\$398.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Elevator 15	Elevator door reopening devices remain open for 17 seconds.	§407.3.3	Provide an elevator door reopening device that remains open for at least 20 seconds and senses an obstruction passing through the opening between 5" - 29" (127 mm - 736 mm) min above the finished floor.	C	\$398.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Elevator 16	Elevator door reopening devices remain open for 12 seconds.	§407.3.3	Provide an elevator door reopening device that remains open for at least 20 seconds and senses an obstruction passing through the opening between 5" - 29" (127 mm - 736 mm) min above the finished floor.	C	\$398.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Toilet tissue dispenser is mounted at a non-compliant distance in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8B	Permanent room identifying signage is mounted at 65" (1651 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 8A	Permanent room identifying signage is mounted at 65.5" (1664 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Right side)	Toilet seat cover dispenser is mounted 5" (127 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Right side)	Chair encroaches over trash bin clear floor space.	§305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at trash bin (ADAAG Figs. 305.3-305.5).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restrooms at Jury Deliberation Room in Courtroom No. 8A (Left side)	Toilet seat cover dispenser is mounted beyond reach ranges at 48.5" (1232 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	D	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Chambers Room No. T8655	Permanent room identifying signage is mounted at 61.5" (1562 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	D	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Accessible toilet compartment (stall) is 37" by 66" (940 by 1676 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	D	\$2,119.74

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Unisex Accessible Restrooms in Front of Courtroom No. 8B	Accessible toilet compartment (stall) is 37" by 66.5" (940 by 1687 mm) deep and it is configured as an alternate stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	D	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 50" (1270 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T8029	Sanitary napkin dispenser is mounted beyond required reach allowed for approach provided and is mounted at 51.25" (1302 mm) above the finished floor.	§308.2.1	Lower or install sanitary napkin dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T8029	Accessible toilet compartment (stall) is 37.5" by 66" (940 by 1676 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	D	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 8F	Permanent room identifying signage is mounted at 65.5" (1664 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Kitchenette at Lounge Area	Sink does not provide the required knee clearance.	§606.2.2	Rework sink to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	D	\$545.58
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Kitchenette at Lounge Area	Vending machine control is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor.	§308.2.1	Lower or install vending machine controls at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	D	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms No. T7028	Toilet seat cover dispenser is mounted beyond reach ranges at 50" (1270 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom 7E	Permanent room identifying signage is mounted at 65.5" (1664 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Men's Accessible Restrooms No. T7026	Accessible toilet compartment (stall) is 37" by 66" (940 by 1676 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	D	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Public Defenders Office No. T519	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 5C	Permanent room identifying signage is mounted at 64.5" (1638 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Conference Room No. T506	Permanent room identifying signage is mounted at 61.5" (1562 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No.5A	Permanent room identifying signage is mounted at 64.25" (1632 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restrooms in Front of Courtroom No. 4B	Accessible toilet compartment (stall) is 37" by 65.5" (940 by 1664 mm) deep and it is configured as an ambulatory stall.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	D	\$2,119.74
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4A	Permanent room identifying signage is mounted at 65.5" (1664 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 4F	Permanent room identifying signage is mounted at 65.5" (1664 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Right side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 4F (Left side)	Chair encroaches over trash bin and paper towel clear floor space.	§305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Right side)	Chair encroaches over trash bin clear floor space.	§305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Left side)	Toilet seat cover dispenser is mounted beyond reach ranges at 50" (1270 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	D	\$0.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Restrooms in Jury Deliberation Room in Courtroom No. 4E (Left side)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). <i>Per 2010 ADA section 35.15(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.</i>	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3A	Permanent room identifying signage is mounted at 65.5" (1664 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 3D	Permanent room identifying signage is mounted at 65.5" (1664 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Transfer Unit Appeals Division	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room at Courtroom No. 7E	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lb.	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 7E (Left Side)	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	D	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room at Courtroom No. 7E	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lb.	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Courtroom No. 7F (Left Side)	Chair encroaches over trash bin and paper towel dispenser clear floor space.	\$305.3	Remove chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Door Leading to Jury Deliberation Room No. T5C06	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lb.	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Women's Accessible Restroom No. T2012 (Between Courtroom No. 2C and 2D)	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lb.	D	\$131.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Courtroom No. 1A	Accessible route leading to jury box has a 4.5" (114 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	D	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2B	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	D	\$120.12
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom (on Right Side) at Jury Deliberation Room in Court Room No. 2C	Chair encroaches over trash bin and paper towel dispenser clear floor space clear floor space.	\$305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	D	\$50.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Court Room No. 2C	Permanent room identifying signage is mounted at 65" (1651 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2C	Permanent room identifying signage does not have Braille or raised characters and is mounted at 65" (1651 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Unisex Accessible Restroom in Jury Deliberation Room at Court Room No. 2E	Chair encroaches into the required diameter wheelchair turnaround space in room.	\$304.3	Relocate chair to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	D	\$55.00
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 1 in Court Room No. 2E	Permanent room identifying signage does not have Braille or raised characters and is mounted at 64" (1626 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95
Courts/Justice	Justice Center Tower	185 Central Ave Atlanta, GA 30303	Holding Cell No. 3 in Court Room No. 2E	Permanent room identifying signage does not have Braille or raised characters and is mounted at 64.5" (1638 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	There is no signage indicating that assistive listening systems are provided inside the courtroom.	\$703.7.2.4	Post signage in courtroom indicating that assistive listening devices are available upon request and/or provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat and/or provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Wheelchair area is at the rear of the sitting area and does not offer the same lines of sight as other seating spaces in front of the assembly area.	\$802.2	Relocate wheelchair areas so as to afford lines of sight over the heads of seated spectators in the first row with an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$640.44
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Accessible route has a 28" (711 mm) clear width at the passage form the general seating area to the seating spaces for counselor and plaintiffs.	\$403.5.1	Rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$250.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Lower portion of the lectern is mounted at 34.5" (876 mm) above the finished floor to the top.	\$808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	The counter at jury box is mounted at 36.5" (927 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Witness stand desk has 26.5" (673 mm) knee clearance.	\$808.4	Provide judge's bench desk mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Court reporter's station doorway opening has a clear width of 21.5" (546 mm).	\$404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$350.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Record's Keeper doorway opening has a clear width of 21.5" (546 mm).	\$404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$350.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Accessible route leading to records keeper's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Jury Deliberation Room in Courtroom No. 9J	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Jury Deliberation Room in Courtroom No. 9J	Maneuvering clearance on the pull side of the door is 7" (178 mm).	\$404.2.4	Reverse door swing (by inverting position of hinges) to comply with the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$898.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9G	There is no signage indicating that assistive listening systems are provided inside the courtroom.	\$703.7.2.4	Post signage indicating that assistive listening devices are available upon request and/or provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9G	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat and/or provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$149.95

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9G	Accessible route has a 30" (762 mm) clear width at the passage from the general seating area to the seating spaces for counselor and plaintiffs.	\$403.5.1	Rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$250.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9G	The counter at jury box is mounted at 35.5" (902 mm) above the finished floor to the top.	\$808.4	Provide at least one accessible counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9G	Lectern is mounted at 35" (889 mm) above the finished floor to the top.	\$808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9G	Accessible route leading to the witness stand has a 12" (305 mm) vertical change in level due to steps	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$650.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9G	Accessible route leading to court reporter's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a curb ramp or ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9G	Court reporter's station doorway opening has a clear width of 27.5" (698 mm).	\$404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Jury Deliberation Room in Courtroom No. 9G	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8G	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat and/or provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8G	Accessible route has a 29" (737 mm) clear width at the passage from the general seating area to the seating spaces for counselor and plaintiffs.	\$403.5.1	Relocate encroaching item or rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$250.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8G	Lectern is mounted at 43" (1092 mm) above the finished floor to the top.	\$808.4	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8G	Accessible route leading to jury box has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$650.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8G	Accessible route leading to witness stand has a 12" (305 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8G	Accessible route leading to judges bench has a 24" (610 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp or lift (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Jury Deliberation Room in Courtroom No. 8G	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Jury Deliberation Room in Courtroom No. 8G	Chair encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	There is no indication that the courtroom provides assistive listening devices.	\$219.1	Post signage indicating that assistive listening devices are available upon request and/or provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$640.44
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat and/or provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Table is encroaching into the wheelchair spaces located at the back of the courtroom.	\$1002.4.4.	Relocate table to provide a clear width of 30" (760 mm) min. and a clear length of 48"(1220 mm) min. measured at 9" (230 mm) min. above the floor surface.	B	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Doorway opening has a clear width of 23" (584 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$250.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Lectern is mounted at 44" (1118 mm) above the finished floor to the top.	\$808.4ph	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Accessible route leading to witness stand has a 14" (356 mm) vertical change in level due to stands.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$650.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Accessible route leading to the witness stand has a 28" (711 mm) clear width.	\$403.5.1	Rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Accessible route has leading to judge's bench has a 28" (711 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of lift or ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Accessible route leading to reporter station has a has a 27.5" (698 mm) clear width.	\$403.5.1	Rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8J	Accessible route leading to reporter's station has a 14" (356 mm) vertical change in level due to steps.	\$403.4	Rework area to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a curb ramp or ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	District Attorney's Office	There is no public access to this floor.	N/A	There is no public access to this floor.	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	Doorway opening has a clear width of 21" (533 mm).	\$404.2.3	Rework doorway (partition) to provide the required 36" (914 mm) min. clear door or entryway width (For doors with openings more than 24" (610 mm) deep).	B	\$600.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	There is no indication that the courtroom provides assistive listening devices.	\$219.1	Post signage indicating that assistive listening devices are available upon request and/or provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$642.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat and/or provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Chairs are encroaching into all the wheelchair spaces located in the courtroom.	\$1002.4.4.	Relocate chairs to provide a clear width of 30" (760 mm) min. and a clear length of 48"(1220 mm) min. measured at 9" (230 mm) min. above the floor surface.	B	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Doorway opening has a clear width of 22.5" (572 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$250.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Defendant's council desk has a non-compliant 26.5" (673 mm) knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Plaintiff's council desk has a non-compliant 26.5" (673 mm) knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Lectern is mounted at 42.5" (1080 mm) above the finished floor to the top.	\$808.4ph	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Accessible route leading to witness stand has a 12" (305 mm) vertical change in level due to steps.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of ramp (2010 ADA Fig. 303.3).	B	\$650.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Accessible route leading to witness stand has a 24" (610 mm) clear width.	\$403.5.1	Rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Court reporter's desk has a non-compliant 27" (686 mm) wide knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor, that is 30" (762 mm) min. wide and has a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	The witness stand counter is mounted at 37" (940 mm) above the finished floor to the top.	\$808.4	Provide witness stand counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor, that is 30" (762 mm) min. wide and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6G	Accessible route leading to judge's bench has a 18" (457 mm) vertical change in level due to steps	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a lift or ramp (2010 ADA Fig. 303.3).	B	\$293.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Accessible Route Leading to Jury Deliberation Room in Courtroom No. 6G	Maneuvering clearance on the push side of the door is 3.5" (89 mm).	\$404.2.4	Remove door closer to comply with the requirements for 12" (304 mm) min. maneuvering clearance on the push side of the door handle side beyond the latch and 48" (1219 mm) min. deep clear floor area (For doors with latch and closer) (2010 ADA Fig. 404.2.4.1).	B	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	There is no indication that the courtroom provides assistive listening devices.	\$219.1	Post signage in courtroom indicating that assistive listening devices are available upon request and/or provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$642.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	Aisle side seat is not identified by a sign or marker.	\$802.4.2	Provide signage identifying the designated access aisle seat and/or provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	Doorway opening has a clear width of 23.5" (597 mm) on each active leaf.	\$404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	B	\$250.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	Lectern is mounted at 43" (1092 mm) above the finished floor to the top.	\$808.4ph	Provide podium mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	Accessible route leading to jury stand has a 12" (305 mm) vertical change in level due to steps	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$650.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	Accessible route leading to witness stand has a 14" (356 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	Accessible route leading to witness stand has a 24" (610 mm) clear width.	\$403.5.1	Rework area to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	The witness stand counter is mounted at 37.5" (952 mm) above the finished floor to the top.	\$808.4	Provide witness stand counter mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 6J	Desk has a non-compliant 25" (635 mm) wide knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor, that is 30" (762 mm) wide and has a 17" (430 mm) horizontal projection.	B	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Main Entrance to Court House	The only means of access to the courthouse is by stairs.	\$403.3	Provide an alternative accessible location or mitigate condition by means of a ramp, elevator or platform lift.	B	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Main Entrance to Court House	This entrance is inaccessible and does not have signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).	B	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$191.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 57.25" (1454 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Toilet tissue dispenser is mounted on the wrong wall	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Paper towel dispenser protrudes into walkway, projecting more than 4" (101 mm) from back wall.	\$307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Toilet tissue dispenser is mounted on the wrong wall.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.25" (1480 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Lavatory is mounted at 34" (863 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Accessible route leading to the witness stand has a 12" (305 mm) vertical change in level due to steps	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	B	\$650.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 9J	Accessible route leading to court reporter's station has a 6" (152 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a ramp (2010 ADA Fig. 303.3).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Jury Deliberation Room in Courtroom No. 9J	Wall/post mounted drinking fountain has a 26.75" (679 mm) knee clearance.	\$602.1	Relocate/rework fountain to provide a 27" (685 mm) min. knee clearance above the finished floor, 30" (762 mm) min. wide and 25" (635 mm) max. deep (2010 ADA Fig. 306.3).	C	\$3,137.43
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Jury Deliberation Room in Courtroom No. 9J	Drinking fountain water flow is less than 4" (102 mm) high.	\$602.6	Adjust to provide a flow of water at least 4" (101 mm) high so as to allow the insertion of a cup under it.	C	\$80.50
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Restroom in Jury Deliberation Room in Courtroom No. 9J	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00

Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Restroom in Jury Deliberation Room in Courtroom No. 9J	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Restroom in Jury Deliberation Room in Courtroom No. 9J	Toilet tissue dispenser is mounted 4.5" (114 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Restroom in Jury Deliberation Room in Courtroom No. 9J	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Restroom in Jury Deliberation Room in Courtroom No. 9J	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 49" (1245 mm) above the finished floor.	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Restroom in Jury Deliberation Room in Courtroom No. 9J	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 51" (1295 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). No remedial work is necessary. Per 2010 ADA section 35.151(c) Safe Harbor, elements in compliance with the specifications in the 1991 Standards are not required to be retrofitted to reflect changes in the 2010 Standards.	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Maneuvering clearance on the pull side of the door is 1.1" (28 mm).	§404.2.4	Provide automatic door opener to comply with requirements for 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Lavatory does not provide the required knee clearance due to cabinet	§606.2.2	Lower or install lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Restroom does not provide the required diameter wheelchair turnaround space in room.	§304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Door swings into toilet compartment clear floor space.	§604.8.1.2	Rework partitions and/or fixtures to provide a 60" by 59" (1524 mm by 1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Jury Deliberation Room in Courtroom No. 9G	Clothes rod is mounted at a non-compliant height above the finished floor.	§308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Jury Deliberation Room in Courtroom No. 9G	Water closet seat is mounted at 15.5" (394 mm) above the finished floor to top (single user)	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Jury Deliberation Room in Courtroom No. 9G	Doorway opening has a non-compliant clear width.	§404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Jury Deliberation Room in Courtroom No. 9G	Restroom does not provide the required diameter wheelchair turnaround space in room.	§304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Family Division	Brochure rack is mounted at 60" (1524 mm) above the finished floor to highest shelf.	§308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor to highest shelf (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Accessible toilet compartment (stall) is 38.5" (978 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Doorway has a 0.5" (13 mm) vertical change of level at door threshold that is not beveled.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Accessible toilet compartment (stall) is 48.5" (1232 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Toilet tissue dispenser is mounted on the wrong wall.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58" (1473 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom in Jury Deliberation Room in Courtroom No. 8G	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom in Jury Deliberation Room in Courtroom No. 8G	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom in Jury Deliberation Room in Courtroom No. 8G	Lavatory has unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom in Jury Deliberation Room in Courtroom No. 8G	Restroom does not provide the required diameter wheelchair turnaround space in room.	§304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Accessible Restroom in Jury Deliberation Room in Courtroom No. 8G	Toilet tissue dispenser is mounted at a non- compliant distance in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Accessible Route Leading to Jury Deliberation Room in Courtroom No. 8J	Clearance between doors in series is less than 48" (1219 mm).	§404.2.6	Reverse door swing to provide 48" (1219 mm) min. clearance between two doors in series (2010 ADA Fig. 404.2.6).	C	\$1,185.60

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Accessible Route Leading to Jury Deliberation Room in Courtroom No. 8J	Cabinet encroaches into maneuvering clearance on the pull side of the door reducing it to 8" (203 mm).	\$404.2.4	Relocate cabinet to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom in Jury Deliberation Room in Courtroom No. 8J	Chairs and furniture encroach into the required diameter wheelchair turnaround space in room.	\$304.3	Remove chairs and furniture to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Secondary Unisex Restroom in Jury Deliberation Room in Courtroom No. 8J	Restroom does not provide the required diameter wheelchair turnaround space.	\$304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Courtroom No. 6G	Doorway has a vertical change of level at door threshold that is not beveled.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Courtroom No. 6G	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Courtroom No. 6G	Accessible toilet compartment (stall) is 48" (1219 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Courtroom No. 6G	Water closet is centered at 19" (483 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Courtroom No. 6G	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Courtroom No. 6G	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Courtroom No. 6G	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Courtroom No. 6G	Doorway has a vertical change of level at door threshold that is not beveled.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	C	\$137.13
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Courtroom No. 6G	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Courtroom No. 6G	Ambulatory accessible compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Courtroom No. 6G	Accessible toilet compartment (stall) is 48.5" (1232 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Courtroom No. 6G	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Courtroom No. 6G	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 57" (1448 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Courtroom No. 6G	Paper towel dispenser protrudes into walkway, projecting more than 4" (102 mm) from back wall.	\$307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Drinking Fountain in Jury Deliberation Room in Courtroom No. 6G	Wall/post mounted drinking fountain has a 26" (660 mm) knee clearance.	\$602.1	Relocate/rework fountain to provide a 27" (685 mm) min. knee clearance above the finished floor, 30" (762 mm) min. wide and 25" (635 mm) max. deep (2010 ADA Fig. 306.3).	C	\$3,137.43
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6G (Right Side)	Toilet seat cover dispenser is mounted beyond reach ranges at 55.25" (1403 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6G (Left Side)	Restroom does not provide the required diameter wheelchair turnaround space.	\$304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6J (Left Side)	Chair encroaches into unisex restroom signage.	\$703.4.2	Remove chair to ensure that a clear floor space of 18" (455 mm) min. by 18" (455 mm) min. centered on the tactile characters, is provided beyond the arc of the door swing, between the closed position and 45° open position (2010 ADA Fig. 703.4.2).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6J (Left Side)	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6J (Left Side)	Toilet tissue dispenser is mounted at a non-compliant distance in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6J (Right Side)	Restroom does not provide the required diameter wheelchair turnaround space in room.	\$304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Counter	Counter is mounted at 40.75" (1035 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$697.18
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Dispositions Counter	Counter is mounted at 40.5" (1029 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Waiting Area by Dispositions Counter	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Clerk Of Superior Court	Maneuvering clearance on the pull side of the stall door is 7.5" (190 mm).	\$404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Clerk Of Superior Court	Accessible toilet compartment (stall) is 48.5" (1232 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (For children's water closet) (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Clerk Of Superior Court	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Clerk Of Superior Court	Toilet seat cover dispenser is mounted beyond reach ranges at a non-compliant height above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Clerk Of Superior Court	Toilet tissue dispenser is mounted on the opposite side wall.	\$604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Clerk Of Superior Court	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Clerk Of Superior Court	Paper towel dispenser protrudes into walkway, projecting 4" (102 mm) from back wall.	\$307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Clerk Of Superior Court	Maneuvering clearance on the pull side of the stall door is 7" (178 mm).	\$404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Clerk Of Superior Court	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Clerk Of Superior Court	Accessible toilet compartment (stall) is 48.5" (1232 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (For children's water closet) (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Clerk Of Superior Court	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Clerk Of Superior Court	Toilet seat cover dispenser is mounted beyond reach ranges at a non-compliant height.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Clerk Of Superior Court	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	District Attorney's Office.	Access to this area is limited as a visitor's pass is required.	N/A	Access to this area is limited as a visitor's pass is required.	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Maneuvering clearance on the pull side of the stall door is 7" (178 mm).	§404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Accessible toilet compartment (stall) is 48.25" (1226 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Toilet seat cover dispenser is mounted at a non-compliant height.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Door has a non-compliant opening force.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Maneuvering clearance on the pull side of the stall door is 7" (178 mm).	§404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Accessible toilet compartment (stall) is 48.25" (1226 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Record Room No. C303	Counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). An alternative writing surface (clipboard) has been provided, no remedial work is necessary.	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Maneuvering clearance on the pull side of the stall door is 7" (178 mm).	§404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Toilet seat cover dispenser is mounted beyond reach ranges at a non-compliant height above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Accessible toilet compartment (stall) is 48" (1219 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (For children's water closet) (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at District Attorney's Office	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Maneuvering clearance on the pull side of the stall door is 7" (178 mm).	§404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Toilet seat cover dispenser is mounted beyond reach ranges at a non-compliant height above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Accessible toilet compartment (stall) is 48.25" (1226 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (For children's water closet) (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at District Attorney's Office	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Marriage, Fire Arms, Records Counter	Information counter is mounted at 39" (991 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Fire Arms License Counter	Counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). An alternative writing surface (clipboard) has been provided, no remedial work is necessary.	C	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Licensing Counter	Counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). An alternative writing surface (clipboard) has been provided, no remedial work is necessary.	C	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Records Counter	Counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). An alternative writing surface (clipboard) has been provided, no remedial work is necessary.	C	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Probate Court	Maneuvering clearance on the pull side of the stall door is 7" (178 mm).	§404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Probate Court	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Probate Court	Accessible toilet compartment (stall) is 48.25" (1226 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (For children's water closet) (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Probate Court	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.25" (1505 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Probate Court	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Probate Court	Lavatory is mounted at 34.75" (883 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Probate Court	Lavatory has partially unwrapped bottom sink pipes.	§606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom by Probate Court	Paper towel dispenser protrudes into walkway, projecting more than 4" (102 mm) from back wall.	§307.2	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Probate Court	Maneuvering clearance on the pull side of the stall door is 6.75" (171 mm).	§404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Probate Court	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Probate Court	Toilet seat cover dispenser is mounted beyond reach ranges at a non-compliant height above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Probate Court	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Probate Court	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Probate Court	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Probate Court	Accessible toilet compartment (stall) is 48" (1219 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom by Probate Court	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Mail Operations Counter	Counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Notary Commissions	Secondary counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Notary Commissions	Work station's desk has a non-compliant 26.5" (673 mm) knee clearance.	§902.2	Desks with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Cashier	Counter is mounted at 40" (1016 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$291.64
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Close File Room	Counter is mounted at 41" (1041 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Maneuvering clearance on the pull side of the stall door is 7" (178 mm).	§404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Accessible toilet compartment (stall) is 48" (1219 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Toilet seat cover dispenser is mounted beyond reach ranges at a non-compliant height.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Maneuvering clearance on the pull side of the stall door is less than 18" (457 mm).	§404.2.4	Rework stall partitions to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Toilet tissue dispenser is mounted on the opposite side wall.	§604.7	Install toilet tissue dispenser on the water closet side wall 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$55.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Toilet seat cover dispenser is mounted beyond reach ranges at a non-compliant height.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Accessible toilet compartment (stall) is 49" (1245 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Record Room	Counter is mounted at 36" (914 mm) above the finished floor.	§904.4.1	The counter is mounted at 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Elevator 14	Elevator door reopening device causes elevator doors to remain open for 16 seconds.	§407.3.3	Adjust elevator door reopening device to remain open for at least 20 seconds.	C	\$398.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Elevator 15	Elevator door reopening devices remain open for 17 seconds.	§407.3.3	Provide an elevator door reopening device that remains open for at least 20 seconds and senses an obstruction passing through the opening between 5" - 29" (127 mm - 736 mm) min above the finished floor.	C	\$398.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Elevator 16	Elevator door reopening devices remain open for 12 seconds.	§407.3.3	Provide an elevator door reopening device that remains open for at least 20 seconds and senses an obstruction passing through the opening between 5" - 29" (127 mm - 736 mm) min above the finished floor.	C	\$398.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Accessible toilet compartment (stall) is 49" (1245 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Accessible toilet compartment (stall) is 48" (1219 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Accessible toilet compartment (stall) is 33" (838 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 59" (1524 mm by 1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Restroom in Jury Deliberation Room in Courtroom No. 9J	Restroom does not provide the required diameter wheelchair turnaround space in room.	§304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Secondary Men's Restroom in Jury Deliberation Room at Courtroom No. 9J	Restroom does not provide the required diameter wheelchair turnaround space in room.	§304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).	C	\$0.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom in Jury Deliberation Room in Courtroom No. 8G	Doorway opening has a clear width of 21.75" (552 mm).	§404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3). Post signage indicating the location of the accessible restroom.	C	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Accessible Restroom in Jury Deliberation Room in Courtroom No. 8G	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism. Post signage indicating the location of the accessible restroom.	C	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom in Jury Deliberation Room in Courtroom No. 8J	Water closet flush control is toward the wall side.	§604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Secondary Unisex Restroom in Jury Deliberation Room in Courtroom No. 8J	Doorway opening has a clear width of 21.5" (546 mm).	§404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3). Post signage indicating the location of the accessible restroom.	C	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6G (Right Side)	Toilet tissue dispenser is mounted at 11.75" (298 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet. Post signage indicating that this is the unisex accessible restroom serving this area.	C	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6G (Left Side)	Doorway opening is less than 32" (813 mm) wide.	§404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3). Post signage indicating the location of the accessible restroom.	C	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6J (Left Side)	Chair encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Unisex Restroom at Jury Deliberation Room in Courtroom No. 6J (Right Side)	Doorway opening has a clear width is less than 32" (813 mm).	§404.2.3	Rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3). Post signage indicating the location of the accessible restroom.	C	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom	Door has a non-compliant opening force.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	D	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom	Door has a non-compliant opening force.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	D	\$131.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Restroom in Jury Deliberation Room in Courtroom No. 9J	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Restroom in Jury Deliberation Room in Courtroom No. 9J	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Post signage indicating the location of the accessible restroom.	D	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Secondary Men's Restroom in Jury Deliberation Room at Courtroom No. 9J	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Post signage indicating the location of the accessible restroom.	D	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Jury Deliberation Room in Courtroom No. 9G	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Accessible Restroom at Jury Deliberation Room in Courtroom No. 9G	Equipment encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate equipment to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	D	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Courtroom No. 8G	Bench encroaches into sign clear floor space	§703.4.2	Relocate bench to ensure that a clear floor space of 18" (455 mm) min. by 18" (455 mm) min. centered on the tactile characters, is provided beyond the arc of the door swing, between the closed position and 45° open position (2010 ADA Fig. 703.4.2).	D	\$55.00
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Counter	There is a total of 5 computer terminals none of them are accessible.	§508	Provide computers with accessible software following section 508 Guidelines.	D	\$1,029.83
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Women's Restroom in Jury Deliberation Room in Courtroom No. 9J	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Post signage indicating the location of the accessible restroom.	D	\$149.95

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Men's Accessible Restroom at Jury Deliberation Room in Courtroom No. 9G	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Post signage indicating the location of the accessible restroom.	D	\$149.95
Courts/Justice	Lewis Slaton Courthouse	136 Pryor Street Atlanta, GA 30303	Staff Restroom at Jury Deliberation Room in Courtroom No. 9G	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Post signage indicating the location of the accessible restroom.	D	\$149.95
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Intake Area	Doorway has a .5" (13 mm) vertical change of level at door threshold.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	B	\$137.13
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Intake Area	Reception counter is mounted at 39" (991 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework reception counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	B	\$372.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Temporary Holding Cell 165	Bench is 8" (203 mm) high.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep and 17"-19" (431mm-485 mm) above the finished floor seat height with armrests and supportive backrest design (for ease in sitting/standing) (2010 ADA Fig.903.4).	B	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Holding Cell 127	Bench is 18" (457 mm) wide.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.	B	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Fingerprint Area	Fixed work surface is mounted at 36" (914 mm) above the finished floor to the top.	§902.3	Rework/replace tables to provide the top of the dining or work surface, mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	B	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Dialysis Room	Boxes encroach passage width.	§403.5.1	Relocate boxes to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	B	\$150.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	General Bathroom 3LD71	Doorway has over 0.5" (13 mm) vertical change of level at door threshold.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (ADAAG Fig. 303.3).	B	\$137.13
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3LB20	Bench is 14" above finished floor and 15" (356 by 381 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep and 17" - 19" (430 mm - 485 mm) max high	B	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3LB20	Bench does not provide the required clear floor space	§903.2	Rework area or relocate bench to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space positioned at the end of the bench seat parallel to the short axis of the bench.	B	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell 104	Doorway opening has a clear width of 30" (762 mm).	§404.2.3	Rework doorway (partition) to provide the required 36" (914 mm) min. clear door or entryway width (For doors with openings more than 24" (610 mm) deep).	B	\$3,125.71
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Courtroom 1	Permanent room identifying signage does not have Braille or raised characters and is mounted at 69" (1753 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.85
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Courtroom 1	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	§404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Courtroom 1	Bench does not provide the required clear floor space	§903.2	Rework area or relocate bench to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space positioned at the end of the bench seat parallel to the short axis of the bench.	B	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Courtroom 1	Path to judge's bench has a 6" (152 mm) vertical change in level.	§303.2	Rework area and provide a 0.25" (6 mm) max. vertical change of level, with a slope no greater than 1:2 or mitigate condition by means of a curb ramp, ramp or platform lift (2010 ADA Fig. 303.2).	B	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Inmate Attorney Booth 2LB49	Permanent room identifying signage does not have Braille or raised characters and is mounted at 60" (1524 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.85
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Inmate Attorney Booth 2LB49	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	§404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Inmate Attorney Booth 2LB49	Stool encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate stool to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Court Intake D15	Bench is 14" (356 mm) high and 14" (356 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep and 17" - 19" (430 mm - 485 mm) max high	B	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Courtroom 2	Permanent room identifying signage does not have Braille or raised characters.	§703.3	Provide signage displaying raised characters on non-glare contrasting surface, Grade 2 Braille text of same information.	B	\$149.85
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Courtroom 3	Permanent room identifying signage does not have Braille or raised characters.	§703.3	Provide signage displaying raised characters on non-glare contrasting surface, Grade 2 Braille text of same information.	B	\$149.85
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	2LB45	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.85
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Permanent room identifying signage is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.85
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Permanent room identifying signage is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$140.85
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Five Designated Accessible Parking Spaces	Frist van access aisle from right to left is 51" (1295 mm) wide	§502.3	Restripe to provide a van-accessible parking space 132" (3352 mm) min. wide and a 60" (1524 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.2 - 502.3).	B	\$1,897.39
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Four Accessible Parking Spaces on the bottom back to back	There is no marked access aisle.	§502.3.1	Restripe area to provide a 60" (1524 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 502.3).	B	\$299.81
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Family Entrance into Courtroom 1	Maneuvering clearance on the pull side of the door is 2" (51 mm).	§404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Five Designated Accessible Parking Spaces	Access aisle has up to a 3% non-compliant surface slope.	§502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Five Designated Accessible Parking Spaces	Second accessible parking space from right to left has a 2.5% non-compliant surface slope.	§502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Five Designated Accessible Parking	Access aisle has a 3.2% non-compliant surface slope.	§502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Five Designated Accessible Parking Spaces	Fourth access aisle from right to left has a 2.6% non-compliant surface slope.	§502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Five Designated Accessible Parking Spaces	Sixth accessible parking space from right to left has up to a 4.2% non-compliant running slope.	§504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restrooms in Intake Waiting Area	Water closet side wall grab bar is mounted at 50.5" (1283 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restrooms in Intake Waiting	Water closet has the rear wall grab bar mounted at 38" (965 mm) perpendicular from side wall to centerline of outer flange.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. to the center line of the outer flange and mount between 33" and 36" (838 mm - 914 mm) above the floor to the top of the gripping surface (2010 ADA Fig 604.5.2)	C	\$380.20

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restrooms in Intake Waiting Area	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Drinking Fountains Next to Restrooms in Intake Waiting Area	Drinking fountain spout outlet (orifice height) is mounted at 37.5" (952 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$697.18
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom Side by Side	Water closet side wall grab bar is mounted at 51" (1295 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom Side by Side	Water closet is centered at 18.5" (470 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in Holding Cell 127	Water closet side wall grab bar is mounted at 52" (1321 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in Holding Cell 127	Water closet is centered at 18.5" (470 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in Holding Cell 127	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in Holding Cell 127	Lavatory mirror is mounted at 53" (1346 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D17	Water closet encroaches over lavatory clear floor space.	\$606.2	Replace fixture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$5,938.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D17	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D17	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D17	Water closet is centered at 25" (635 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D17	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D17	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$545.58
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	General Bathroom 3LD71	Shower controls requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$200.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	General Bathroom 3LD71	Bathtub has non-compliant grab bar configuration. It is missing one back wall grab bar.	\$607.4	Install a 24" (609 mm) min. control end wall grab bar, two 24" (609 mm) min. long back wall grab bars, a 12" (304 mm) min. long head wall grab bar mounted between 33"- 36" (838 mm - 914 mm) above the finished floor to top of bar (2010 ADA Fig. 607.4.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	General Bathroom 3LD71	Shower head is a fixed-type unit.	\$607.6	No replacement required for purposes of suicide protection.	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	General Bathroom 3LD71	Transfer shower stall has a high curb.	\$608.7	Rework transfer shower to provide a beveled curb that does not exceed 0.5" (12 mm) in height.	C	\$390.54
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D28 (Suicide Prevention)	Water closet is centered at 27" (686 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D28 (Suicide Prevention)	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D28 (Suicide Prevention)	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$5,938.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D28 (Suicide Prevention)	Lavatory mirror is mounted at 58" (1473 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower Area	Doorway has a vertical change of level at door threshold.	\$404.2.5	Rework door threshold to provide a 0.5" (12 mm) max. change of level, beveled with a slope no greater than 1:2.	C	\$137.13
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower Area	Bathtub has non-compliant grab bar configuration.	\$607.4	Install a 24" (609 mm) min. control end wall grab bar, two 24" (609 mm) min. long back wall grab bars, a 12" (304 mm) min. long head wall grab bar mounted between 33"- 36" (838 mm - 914 mm) above the finished floor to top of bar (2010 ADA Fig. 607.4.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower Area	Transfer shower stall has a 4" (102 mm) high curb.	\$608.7	Rework transfer shower to provide a beveled curb that does not exceed 0.5" (12 mm) in height.	C	\$390.54
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower Area	Transfer shower has non-compliant grab bar configuration.	\$608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall, and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.3.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower Area	Lavatory mirror is mounted at 58.5" (1486 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Female Inmate Cell (Suicide Prevention)	Water closet side wall grab bar is mounted at 18.5" (470 mm) perpendicular from rear wall to centerline of its inner flange.	\$604.5.1	Relocate side wall grab bar at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Female Inmate Cell (Suicide Prevention)	Water closet is centered at 28" (711 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Female Inmate Cell (Suicide Prevention)	Water closet seat is mounted at 14.5" (368 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Female Inmate Cell (Suicide Prevention)	Lavatory does not provide the required knee clearance.	\$606.2.2	Replace lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$5,938.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Female Inmate Cell (Suicide Prevention)	Toilet tissue dispenser is mounted behind the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$293.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Toilet tissue dispenser is mounted behind water closet.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$293.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Water closet is centered at 25" (635 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Lavatory does not provide the required knee clearance.	\$606.2.2	Replace lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$5,938.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Lavatory mirror is mounted at 57" (1448 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Call button is mounted at 55" (1397 mm) above the finished floor to highest operable part.	\$308.2.1	Lower or install call button at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.2.1).	C	\$293.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Next to Room 3LB36	TV protrudes into walkway, projecting 20" (508 mm) from back wall, and is mounted at 72" (1829 mm) above the finished floor to its bottom leading edge.	\$307.2r	Raise TV or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge or provide a cane detectable element (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3LB20	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3LB20	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3LB20	Water closet is centered at 14.5" (368 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3LB20	Lavatory does not provide the required knee clearance.	\$606.2.2	Replace lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$5,938.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3LB20	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3LB20	Accessible toilet compartment is 42.5" (1080 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 59" (1524 mm by 1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3S Clinic	Table encroaches over video phone clear floor space.	\$305.3	Relocate table to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (ADAAG Figs. 305.3-305.5).	C	\$55.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	General Floor	Drinking fountain spout outlet (orifice height) is mounted at 40.5" (1029 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$697.18
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Corridor in Front of Room 800	Suggestion box is mounted at 55" (1397 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install suggestion box at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Room 100	Telephone is mounted at 50" (1270 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$293.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Restroom in Room 100	Stall doorway opening has a clear width of 27.5" (698 mm).	\$404.2.3	Rework stall doorway (partitions) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	C	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Restroom in Room 100	Accessible toilet compartment is 36.75" (933 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 59" (1524 mm by 1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Restroom in Room 100	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Restroom in Room 100	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Restroom in Room 100	Water closet seat is mounted at 15.5" (394 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Restroom in Room 100	Lavatory does not provide the required knee clearance.	\$606.2.2	Replace lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$545.58
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower in Room 100	Roll-in shower entryway is 30.5" (775 mm) wide.	\$608.2	Rework partitions to provide a 60" (1525 mm) min. clear entryway width to the shower compartment (Fig. 608.2.2).	C	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower in Room 100	Roll-in shower stall has a 5" (127 mm) high curb.	\$608.7	Rework roll-in shower curb so it does not exceed 0.5" (12 mm) in height.	C	\$390.54
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower in Room 100	Shower stall is 34.5" by 67" (876 by 1702 mm) and does not have the required clear floor space.	\$608.2	Reconfigure room's fixtures and/or offset partitions to provide a 30" by 60" (762 mm by 1524 mm) min. shower stall with the required 30" by 60" (762 mm by 1525 mm) min. clear floor space (Fig. 608.2.2).	C	\$2,502.43
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower in Room 100	Roll-in shower does not have grab bars.	\$608.3.1	Install grab bars on back and side walls at 6" (150 mm) max. from adjacent walls and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.3.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell 104	Fixed tables have a non-compliant 22" (559 mm) wide knee clearance and non-compliant clear floor space provided.	\$902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$372.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell 104	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell 104	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell 104	Water closet is centered at 42" (1067 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$5,938.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell 104	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell 104	Lavatory does not provide the required knee clearance.	\$606.2.2	Replace lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$5,938.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell 104	Lavatory mirror is mounted at 59.75" (1518 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Stairs in General Area	Stairs protrudes into walkway, reducing head clearance.	\$307.4	Provide guardrails or other barriers where the vertical clearance is less than 80" (2032 mm) high. The leading edge of guardrail or barrier needs to be 27" (685 mm) max above the finish floor (2010 ADA Fig. 307.4).	C	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Purchasing Machine in General Area	Purchasing machine protrudes into walkway, projecting 7" (178 mm) from back wall, and is mounted at 32" (813 mm) above the finished floor to its bottom leading edge.	\$307.2b	Relocate and mount at or below 27" (685 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3N Competency Restoration Program	Telephone is mounted at 50" (1270 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$293.13
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	3N Competency Restoration Program	No tables provided in this area.	\$902.2	Provide seating in this area with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in 3N Competency Restoration Program	Stall opening has a clear width of 28" (711 mm).	\$404.2.3	Rework stall doorway (partitions) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	C	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in 3N Competency Restoration Program	Accessible toilet compartment is 37" (940 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 59" (1524 mm by 1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in 3N Competency Restoration Program	Water closet is centered at 19.5" (495 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in 3N Competency Restoration Program	Water closet seat is mounted at 14" (356 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in 3N Competency Restoration Program	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in 3N Competency Restoration Program	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Bathroom in 3N Competency Restoration Program	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$545.58
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Purchasing Machine in 3N Competency Restoration Program	Purchasing machine protrudes into walkway, projecting 6" (152 mm) from back wall, and is mounted at 36" (914 mm) above the finished floor to its bottom leading edge.	\$307.2b	Relocate and mount at or below 27" (685 mm) above the finished floor to its bottom leading edge, or place a cane-detectable element or barrier underneath (2010 ADA Fig. 307.2).	C	\$293.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Court Intake D15	Water closet does not have a side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Court Intake D15	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Court Intake D15	Water closet is centered at 18.25" (464 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Court Intake D15	Water closet seat is mounted at 15" (381 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Court Intake D15	Lavatory does not provide the required knee clearance.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$545.58
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Court Intake D15	Accessible toilet compartment is 40.5" by 49" (1029 by 1245 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 59" (1524 mm by 1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$452.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Court Intake D15	Toilet tissue dispenser is mounted behind the water closet.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Main Lobby	Telephone is mounted at 54" (1372 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$293.13
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Main Lobby	Telephone does not provide TTY sign.	216.9	Provide sign identified by the International Symbol of TTY complying with 703.7.2.2	C	\$350.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Main Lobby	Drinking fountain spout outlet (orifice height) is mounted at 36.5" (927 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet	C	\$697.18
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Accessible compartment stall 39" (991 mm) wide.	\$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$2,119.74
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Only one ambulatory accessible stall is provided.	213.3.1	As per 2010 ADA 213.3.1, when there are six or more toilet compartments, then one stall shall be a standard accessible stall and in addition provide one ambulatory stall. Rework partitions to provide a 60" by 56" (1524 mm by 1422 mm) min. standard stall.	C	\$2,119.74
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Water closet side wall grab bar is mounted at 38" (965 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Water closet has a 36" (914 mm) long side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Water closet side wall grab bar is mounted at 18" (457 mm) perpendicular from rear wall to centerline of its inner flange.	\$604.5.1	Relocate side wall grab bar at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Water closet is centered at 19.5" (495 mm) from side wall (Ambulatory Stall).	\$604.2	Relocate water closet and center between 17" and 19" (431 mm - 482 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 62" (1575 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58" (1473 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Men's Restroom in Main Lobby	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 55" (1397 mm) above the finished floor	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Only an ambulatory accessible stall has been provided.	213.3.1	As per 2010 ADA 213.3.1, where toilet compartments are provided, at least one wheel chair accessible compartment shall be provided. Rework partitions to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water	C	\$0.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Accessible stall is 38" (965 mm) wide.	\$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$2,119.74
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Water closet is centered at 19.5" (495 mm) from side wall (Single user).	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Water closet seat is mounted at 20.5" (521 mm) above the finished floor to top (single user)	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 61.25" (1556 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$545.58
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Sanitary napkin dispenser is mounted beyond required reach allowed for approach provided and is mounted at 63" (1600 mm) above the finished floor.	\$308.2.1	Lower or install at 48" (1219 mm) max. above the finished floor for forward approach to dispenser (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58" (1473 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Women's Restroom in Main Lobby	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor	\$308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Vending machine in Main Lobby	Vending machine controls are mounted beyond required reach allowed for approach provided and is mounted at 56" (1422 mm) above the finished floor.	\$308.2.1	Lower or install at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00

**Fulton County ADA Transition Plan
JUSTICE/COURTS
Appendix 7-8**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	General Bathroom 3LD71	Shower has no control wall grab bar.	\$607.4.1.2	Install a 24" (609 mm) min. control end wall grab bar, two (2) 24" (609 mm) min. long back wall grab bars, a 12" (304 mm) min. long head wall grab bar and mount between 33" and 36" (838 mm - 914 mm) to the top of grab bars (2010 ADA Fig. 607.4.2)	C	\$380.20
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Shower Area	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$291.64
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Dining Area in Room 100	Fixed tables have non-compliant clear floor space provided.	\$902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$372.14
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell D28 (Suicide Prevention)	Bed is mounted at 16" (406 mm) above the finished floor.	NA	As best practice, provide 17-19" (431mm-485 mm) above the finished floor to the top bed height.	D	\$500.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Female Inmate Cell (Suicide Prevention)	Bed is mounted at 16" (406 mm) above the finished floor.	NA	As best practice, provide a bed 17-19" (431mm-485 mm) above the finished floor to the top bed height.	D	\$500.00
Courts/Justice	Main Jail (Rice St)	901 Rice Street Atlanta, GA 30318	Cell B25	Bed is mounted at 26" (660 mm) above the finished floor.	\$903.5	As best practice, provide 17-19" (431mm-485 mm) above the finished floor to the top bed height.	D	\$500.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Conference Room 129	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character.	\$703.4.1	We recommend as best practice installing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$55.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Room 103	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character.	\$703.4.1	We recommend as best practice installing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$55.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Office Side by Side Room 103	Door has a non-compliant opening force of 12 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Three Accessible Parking Spaces on Right Side of Main Entrance	First accessible parking space from the right has up to a 2.7 % non-compliant running slopes.	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Conference Room 129	TV does not have the closed caption feature turned on.	\$36.303(e)	Ensure TV set has the closed caption feature on during business hour.	C	\$55.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Women's Restroom in Main Lobby	Paper towel dispenser protrudes into walkway, projecting more than 4" (102 mm) from back wall.	\$307.2	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Women's Restroom in Main Lobby	Toilet seat cover dispenser is mounted beyond reach ranges at 52" (1321 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Women's Restroom in Main Lobby	Lavatory has partially exposed bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Women's Restroom in Main Lobby	Toilet tissue dispenser is mounted at 32.5" (826 mm) from rear wall to centerline.	\$604.9.6	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 14"-19" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Women's Restroom in Main Lobby	Toilet tissue dispenser is mounted 4.5" (114 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Men's Restroom in Main Lobby	Toilet tissue dispenser is mounted at 32.5" (826 mm) from rear wall to centerline.	\$604.9.6	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 14"-19" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Men's Restroom in Main Lobby	Paper towel dispenser protrudes into walkway, projecting more than 4" (102 mm) from back wall.	\$307.2	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Men's Restroom in Main Lobby	Toilet tissue dispenser is mounted 4.25" (106 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Men's Restroom in Main Lobby	Toilet seat cover dispenser is mounted beyond reach ranges at 52" (1321 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Men's Restroom in Main Lobby	Lavatory has partially exposed bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Women's Restroom in Main Lobby	Water closet has a 24" (610 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Men's Restroom in Main Lobby	Water closet has a 24" (610 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).	C	\$380.20
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Conference Room 129	Furniture encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to allow the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	D	\$55.00
Courts/Justice	Medical Examiner's Center	430 Pryor Street SW Atlanta, GA 30312	Room 103	Furniture encroaches over clear floor space beyond door swing.	\$305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).	D	\$55.00